



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

Telephone:+91-40-20203009	Date:28.05.2024
Website : www.tifrh.res.in	Email: krishnaae@tifrh.res.in

NOTICE INVITING TENDER

(TWO PART PUBLIC TENDER) for the following works:

Supply, Installation, Testing and commissioning of Air Distribution works for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.	
निविदा सं. Tender No.	TIFR/PD/CF24-22/240146
निविदा का प्रकार Type of Tender	Two Part Tender (Part-I: Technical Bid and Part- II: Price Bid)
अनुमानित लागत Estimated Cost	Rs.1,03,56,089/-
ईएमडी की लागत Cost of EMD	Rs.2,07,122/- (डिमांड ड्राफ्ट "टीआईएफआर सेंटर फॉर इंटरडिसिप्लिनरी साइंसेस" के पक्ष में तैयार किया जाना है, जो हैदराबाद में देय है (तकनीकी बोली भाग - I के साथ संलग्न किया जाना है)।" Rs.2,07,122/- (Demand Draft to be drawn in favor of "TIFR Center for Interdisciplinary Sciences", Payable at Hyderabad (To be enclosed with the Technical Bid Part – I).
बोली पूर्व बैठक और समय Pre bidding meeting & Time	31.05.2024 at 11:00 Hrs
निविदा प्रस्तुत करने की अंतिम तिथि Last Date for Submission of Tender	10.06.2024 by 13:00 Hrs
बोली खोलने की तिथि (केवल भाग-I: तकनीकी बिड) Date of Opening Bids(Only Part-I: Technical Bid)	10.06.2024 at 15:00 Hrs
निविदा शुल्क Tender Fee	"रु.1,000/- रुपये (हैदराबाद में देय "टीआईएफआर सेंटर फॉर इंटरडिसिप्लिनरी साइंसेस" के पक्ष में तैयार किया जाने वाला डिमांड ड्राफ्ट (तकनीकी बोली भाग-I के साथ संलग्न किया जाना है)। Rs.1,000/- (Demand Draft to be drawn in favor of "TIFR Centre for Interdisciplinary Sciences "Payable at Hyderabad (To be enclosed with the Technical Bid Part –I)).



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

- "यदि भाग "I" और भाग "II" बोलियों को अलग-अलग लिफाफों में सील नहीं किया जाता है तो निविदा को अस्वीकार कर दिया जाएगा।"
- In case the Part "I" and Part "II" bids are not sealed in separate envelopes the tender will be rejected.
- तकनीकी बोली में मूल्य का कोई संकेत नहीं होना चाहिए।
The technical bid should not contain any indication of the price.
- निविदा शुल्क और ईएमडी के भुगतान के बिना प्राप्त तकनीकी बोली को सरसरी तौर पर अस्वीकार कर दिया जाएगा। The Technical Bid received without payment of tender fees and EMD shall be summarily rejected.

संपर्क: श्री कृष्ण, दूरभाष: 040- 20203009 किसी भी तकनीकी या वाणिज्यिक शर्तों के लिए निविदा में उल्लिखित स्पष्टीकरण Contacts: Mr. Krishna, Tel: 040- 20203009 for any technical or commercial terms clarifications mentioned in the tender.

Sealed tenders are invited for the aforesaid works from contractors having similar work experience in reputed Research Institutions, Universities, Central Government/Public Sector Undertaking, Private Laboratories, Multinational Companies, etc. Interested contractors who are satisfying prequalification criteria stipulated by TIFR-Hyderabad shall only submit their bids. For further details and any clarification on the tender you may please contact Head-Technical Services, Survey No.36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad-500046.

Last date for submission of the tender is 10.06.2024 by 13:00 Hrs.

(Rajasekhar. R)

Head-Technical Services



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

TENDER DOCUMENT

Supply, Installation, Testing and commissioning of Air Distribution works for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.

NAME OF THE TENDERER:.....

Address:

.....
.....
.....

Last date of submission of the tender: On or before 10.06.2024 by 13:00 Hrs



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

TECHNICAL BID

VOLUME-I

Supply, Installation, Testing and commissioning of Air Distribution works for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

Tender Notice	:	TIFR/PD/CF24-22/240146
Name of Work	:	Supply, Installation, Testing and commissioning of Air Distribution works for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.
Location	:	Tata Institute of Fundamental Research Survey No. 36/P, Gopanpally village, Serilingampally Mandal, Ranga Reddy District, Hyderabad – 500046.
Estimated Cost	:	Rs.1,03,56,089/-
EMD	:	Rs.2,07,122/- (Demand Draft to be drawn in favor of “TIFR Center for Interdisciplinary Sciences”, Payable at Hyderabad (To be enclosed with the Technical Bid Part – I).
Delivery Period	:	180 Days (Completion Period)
Validity	:	Seventy Five (75) days after opening of Part-I, Technical Bid



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

INDEX

SECTION	DESCRIPTION	PAGE NO.
SECTION I	IMPORTANT INFORMATION	7-9
SECTION II	ELIGIBILITY CRITERIA FOR QUALIFICATION OF TENDER	10-17
SECTION III	NOTICE & INSTRUCTIONS	18-23
SECTION IV	GENERAL INFORMATION	24-36
SECTION V	TECHNICAL SPECIFICATIONS	37-43
SECTION VI	ANNEXURES	44-49
SECTION VII	FINANCIAL BID (PART II)	50-55



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

SECTION-I

IMPORTANT INFORMATION

INTRODUCTION

The Tata Institute of Fundamental Research is a National Centre of the Government of India, under the umbrella of the Department of Atomic Energy, as well as a deemed University awarding degrees for master's and doctoral programs. Tata Institute of Fundamental Research Centre for Interdisciplinary Sciences, Hyderabad invites bids for the following work:

Supply, Installation, Testing and commissioning of Air distribution works for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.

1. PARTICULARS

a)	Location	TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.
b)	Pre-Bid Meeting Date & Time	31.05.2024 at 11:00 Hrs
c)	Closing date & time of receipt of bids	10.06.2024 by 13:00 Hrs
d)	Date & time of opening of Sealed Cover-I containing Technical Bid	10.06.2024 at 15:00 Hrs
e)	Date of opening of Sealed cover-II containing Financial of eligible bidders	To be intimated to eligible bidders subsequently which is likely to be within 7 days after opening of Technical Bid

2. GENERAL INSTRUCTIONS

- 2.1. TIFR shall award the contract for the project through the two Bid systems.
- 2.2. The Contractor is advised to visit and examine the site of work and its surroundings and obtain any information that may be necessary, in addition to those provided in this document. The Contractor shall be deemed to have fully acquainted himself about the site condition, whether he inspects it or not.
- 2.3. The Contractor should adhere to the building bye-laws applicable for the area.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

- 2.4. All clarifications shall be sought before the date of pre-bid meeting. The bidders may make suggestions which shall be considered during the Pre Bid Meeting. No further clarifications shall be issued after the issue of noteworthy replies to the pre-bid queries.
- 2.5. The submission of the bid by Contractor would imply that they have carefully read and agreed to the terms and conditions contained in this bid document.
- 2.6. The bid for the work shall remain open for acceptance for a period of 75(seventy five) days from the date of submission of the bids, which period may be extended by mutual agreement and the Contractor shall not cancel or withdraw the offer during this period.
- 2.7. This bid document shall form a part of the contract agreement.

3. SUBMISSION OF BIDS

Bids shall be submitted to Head- Technical Services, TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist, Hyderabad-500046 in a sealed Master envelope super scribed "Bid for Supply, Installation, Testing and commissioning of Air Distribution works for Petawatt Laser Facility at TIFR with our enquiry no. and due date, containing two separate sealed covers clearly super scribed as "Technical Bid" and "Financial Bid" before the closing date and time of submission in the following manner:

- a) "Technical Bid": This will contain Technical part, Eligibility Documents along with testimonials. Earnest Money Deposit (EMD).
- b) "Financial Bid": This will contain the complete bidding document with duly filled in Schedule of Financial Quote of Financial Bid & Tender Drawings.

The Bids without signature of the authorized person of bidder and seal, without EMD, with conditions or conditional rebates shall be summarily rejected.

4. EVALUATION OF BID

- 4.1. **EVALUATION OF TECHNICAL BID:** The bids received will first be first opened and will be examined for EMD/ Declaration Letter, Eligibility Criteria, Conditions, etc. Conditional Tenders and Tenders without EMD/Declaration Letter shall be summarily rejected.
- 4.2. **EVALUATION OF FINANCIAL BID:** The Financial Bid should contain the complete bid document with duly filled in Schedule of Financial Quote of Financial Bid and signed Tender drawings. Financial Bids of Technically qualified Bidders will only be opened. Work will be awarded to lowest bidder (L1) based on their quotes after making necessary arithmetical checks.

5. SCOPE & OBJECTIVE

The Objective of the tender is to **Supply, Installation, Testing and commissioning of Air Distribution works for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046** as per the specifications and Bill of quantities mentioned in the Financial Bid.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

Period of Completion of Work: 180 days from the date of issue of work order

Defect Liability Period: 12 months from the date of handing over of completed system as per tender.

6. PAYMENT SCHEDULE:

The contractor shall submit the bills for payments along with a detailed statement showing the actual works carried out under different heads of items in the format specified by the TIFR. Minimum value of the work for interim payment (**two Running Bill**) shall be 35% of the work order value. All interim and final bills will be settled based on the joint measurements of each item of work and certified by TIFR Engineer. The bills for nonperishable materials on site may also be submitted and the payment by TIFR against the same shall be to the maximum extent of 60% of the value of these materials on production of sufficient documentary evidence i.e. Original invoice, Inventory, etc. All interim bills will be paid within **30** days from the date of submission and Final Bill along with all relevant documents will be settled within **30** days from the date of submission with certification of TIFR Engineer.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

SECTION-II

ELIGIBILITY CRITERIA FOR TENDER QUALIFICATION

Supply, Installation, Testing and commissioning of Air Distribution works for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.

• **Eligibility criteria:**

1. The Agencies/Contractors shall hold a valid labor license issued by appropriate authority and must be valid throughout the contractual period.
2. HVAC dealers or contractors are eligible to submit the offer.
3. IT Returns for the last three consecutive financial years ended on March 31, 2024 audited by CA.
4. The Agencies/Contractors should have an average annual turnover of **Rs.41.42** lakhs during three previous financial years ending March 31, 2024.
5. The Agencies/Contractors should have a latest solvency certificate issued by any nationalized bank of value not less than **Rs.41.42**.
6. The Agencies/Contractors should not have incurred any loss in more than two years during the immediate last five consecutive financial years, duly certified by the Chartered Accountant.
7. The Agencies/Contractors should have valid PAN from Income Tax Authority, GST registration No. etc. and any other registration applicable/mandatory for contract.
8. The Agencies/Contractors should have executed similar installations of Ducting works for Clean rooms or similar works successfully at least
 - 8.1. One similar work costing **Rs.82.84** Lakhs or
 - 8.2. Two similar works costing **Rs.62.13** Lakhs or
 - 8.3. Three similar works costing **Rs.41.42** Lakhs during the last 7 financial years ended on the end date of receiving tender for Research Institutes, Universities, Private Laboratories, R & D institutes, etc. in any Government /PSU/Private organizations of repute.

The value of executed works shall be brought to the current costing level by enhancing the actual value of work at a simple rate of 7% per annum calculated from the date of completion to the last date of receipt of applications for tender.

The Agencies/Contractors should furnish copies of work orders along with BOQ and completion certificates are mandated from the clients in support of the above.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

Note:

- ❖ Agencies/Contractors are advised to inspect the site to understand the scope of work comprehensively before submission of tender.
- ❖ Agencies/Contractors should arrange the site inspection to TIFR officials for the qualifying works at their own cost if required.
- ❖ Agencies/Contractors should have a full-fledged in-house project management team to undertake the jobs.
- ❖ The Agencies/Contractors shall **strictly furnish** aforesaid information in the formats/schedules given. **Non adherence to furnishing of information in the given format/schedules given will lead to disqualification of tender.**
- ❖ Instructions to Agencies/Contractors for furnishing the information is given as under:
 - Each page of the application shall be signed by a person having necessary authority to do so.
 - If the space in the proforma is insufficient for furnishing full details, such information may be given in separate sheets.
 - Applicants are required to furnish information against each item of the application. In case a certain item is not applicable, please write NA. Application containing incorrect and or inadequate information is liable to be rejected.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

SCHEDULE – A
BASIC INFORMATION

1. Name of the firm :
2. a) Address :
- b) Telephone / Fax No. :
- c) Mobile No. Contact Person :
- d) PAN No. :
- e) GST Registration No. :
- f) Labour License Details :
- Branch Office if any in Hyderabad :
3. Type of Organization (Proprietorships / Partnership) Ltd. Co. / Co-Operative) (Copy of relevant document to be enclosed) :
4. Date of Incorporation :
5. Nature of Business :
6. Experience as prime Agencies/ Contractors (in Yrs.) :
7. Name and address of Bankers :
8. Organization chart of the Company including names and positions of directors / key personnel :

Signature of the Applicant (s)



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
 भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
 (An Autonomous Institute of the Department of Atomic Energy,
 Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
 36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

SCHEDULE – B

Major Air Distribution Works (Copies of the completion certificate to be enclosed)

A. Similar work of costing **Rs.82.84** lakhs or two similar works of costing **Rs.62.13** lakhs or 3 similar works of costing **Rs.41.42** Lakhs during last 7 financial years ended on end date of receiving tender for Research Institutes, Universities, Private Laboratories, R & D institutes, etc

S r. N o	Name of the project & Address	Descr iption of work in brief	Name of the Engineer	Name of the client also indicate whether Govt or semi Govt or Pvt body with full postal address	Contract Amount in Rs.	Year of commen ceme nt	Date of Completion		Whether work was left /uncomplete d or the contract was terminated from either side? Give Details.	Any other relevant information relevant information
							Stipula ted	Actual		
1.										
2.										



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

B. List of works in progress above Rs.41.42 lakhs.

S No.	Name of the project & Address	Description of work in brief	Name of the Engineer with full postal address	Name of the Client. Also indicate whether Govt. or semi Govt. or Pvt. Body with full postal address	Contract Amount in (Rs.)	Date of Completion	Present stage of work with reasons if the work is getting delayed	Any other relevant information
1.								
2.								
3.								

Signature of the Applicant (s)



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

SCHEDULE – C

TECHNICAL PERSONNEL & SPECIAL EXPERIENCE

List of technical personnel in your establishment giving details about their technical qualification and experience

Sr No	Name	Age	Qualifications	Project Experience	Nature of works handled	Name of the project Handled	Date from which employed in your organization	Indicate special experience in Air Conditioners installation & Testing projects in which were employed
1								
2								

2. Indicate other points if any to show your technical and managerial competency to indicate any important point in your favour.

Signature of the Applicant(s)



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

SCHEDULE – D

FINANCIAL POSITION AND WORKING RESULTS

		2021-22	2022-23	2023-24
1	Annual turnover	:	Rs.	
2.	Net Profit	:	Rs.	
3.	Credit Facilities from the Bank	:	Rs.	
a)	Cash Credit	:	Rs.	
b)	Overdraft Limit	:	Rs.	
c)	Guarantee	:	Rs.	
d)	Others	:	Rs.	
4.	Certificate from the Bankers regarding financial soundness of the applicant	:	Enclosed (Yes / No)	
5.	Solvency Certificate from the Bankers	:	Enclosed (Yes / No)	

Signature of the Application (s)



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

SCHEDULE – E

MISCELLANEOUS INFORMATION

- 1 Whether it would be possible to process Bank :
Guarantee for various advances
during execution of the work.
- 2 Details of Civil Suits / Litigations arose during :
execution of the contracts in the last 5 years.
- 3 Latest Income Tax Clearance Certificate :
- 4 Name of the two senior official of Organizations :
preferably Govt./Semi Govt/ Autonomous/ Public
Sector Organization for whom you have
executed important and major HVAC/Air
Distribution works, who may be directly
contracted by TIFR to gather information about
your ability, competence and capacity of your
work/organization/etc.
- 5 Number of Supplementary sheets attached. :

Signature of the Applicant



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

SECTION-III

NOTICE & INSTRUCTIONS

1. Sealed item rate tenders in the prescribed form are invited from Head-Technical Services, Tata Institute of Fundamental Research, Centre for Interdisciplinary Services, Hyderabad, for the following:

Tender Notice No.	TIFR/PD/CF24-22/240146
Name of Work	Supply, Installation, Testing and commissioning of Air Distribution works for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.
Estimated Cost	Rs.1,03,56,089/-
Time Limit	180 days (Completion Period)
Earnest Money Deposit	Rs.2,07,122/- (Demand Draft to be drawn in favor of "TIFR Centre for Interdisciplinary Sciences "Payable at Hyderabad (To be enclosed with the Technical Bid Part –I)).
Tender Fee	Rs.1000/- (Rupees One Thousand only) (Demand Draft to be drawn in favor of "TIFR Centre for Interdisciplinary Sciences "Payable at Hyderabad (To be enclosed with the Technical Bid Part –I)).
Last Date & Time of Submission of Tender	10.06.2024 by 13:00 Hrs
Date & Time of Opening of Technical Bid	10.06.2024 at 15:00 Hrs

2. Submission of Tender & Opening:

Tenders shall be submitted in a sealed envelope super scribed with Tender enquiry No., Due Date and with heading as **"Supply, Installation, Testing and commissioning of Air Distribution works for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046."** containing two separate sealed covers clearly super scribed as **"TECHNICAL BID"** and **"FINANCIAL BID"** on or before the closing date and time of submission in the following manner:

"TECHNICAL BID": This will contain the following:

- a) Proof of Tender Cost paid already



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

b) Earnest Money Deposit as stipulated

c) Schedules giving information on Eligibility Criteria with supporting documents specified for tender qualification.

“FINANCIAL BID”: Signed copy of the Financial Bid quoting amount in the stipulated format and signed copies of the tender drawings.

3.Earnest Money Deposit (EMD): EMD shall be submitted in the form of Demand Draft / Pay Order / Banker's cheque issued by a Scheduled Bank, drawn in favor of **“TIFR Center for Interdisciplinary Sciences”**, (To be enclosed with the Technical Bid (Part-I))

Earnest Money Deposit (EMD): Every Bidder has to pay EMD of amount as specified elsewhere in this tender by Demand Draft in favor of **“TIFR Center for Interdisciplinary Sciences”** along with the offer. Quotations received without EMD shall be rejected and no correspondence whatsoever will be entertained. For successful bidders the EMD will be adjusted against Performance Guarantee and will be refunded after completion of work /supply of material at site and for unsuccessful bidders EMD will be refunded after placing the order to successful bidder.

4. Performance guarantee

The tenderer, whose tender is accepted, will be required to furnish a performance guarantee of 2.5% of the tendered amount within 7 (seven) working days from the date of intimation. This guarantee shall be in the form Demand Draft / Pay Order / Banker's cheque / Deposit or Government Securities / Fixed Deposit Receipt (FDR) or Guarantee Bonds (BG) of any Scheduled Bank in accordance with the form as Annexure – I hereto. In case a fixed deposit receipt of any Bank is furnished by the contractor to TIFR as part of the performance guarantee and the Bank is unable to make payment against the said fixed deposit receipt, the loss caused thereby shall fall on the contractor and the contractor shall forthwith on demand furnish additional security to TIFR to make good the deficit.

The Performance Guarantee shall be initially valid up to the stipulated date of completion **plus 60 days** beyond that. In case the time for completion of work gets enlarged, the contractor shall get the validity of performance Guarantee extended to cover such enlarged time for completion of work. The performance guarantee shall be returned to the contractor, without any interest, after recording of the completion certificate for the work by the competent authority.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

The Engineer-in-charge shall make a claim under the Performance guarantee for amounts to which TIFR entitled under the contract (notwithstanding and / or without prejudice to any other provisions in the contract agreement) in the event of:

- a) Failure to attend and rectify the problems in the guarantee period, in which event the Engineer- in-charge may claim the full amount of the Performance guarantee.
- b) Failure by the contractor to pay TIFR, Hyderabad any amount due, either as agreed by the contractor or determined under any of the Clauses / Conditions of the agreement, within 30 days of the service of notice to this effect by Engineer-in-charge.

In the event of the contract being determined under provisions of any of the relevant clauses of the agreement, the performance guarantee shall stand forfeited in full and shall be absolutely at the disposal of TIFR, Hyderabad.

5.Security Deposit: The tenderer, whose tender is accepted, will also be required to furnish by way of Security Deposit for fulfillment of his contract, an amount equal to 5% of the tendered value of the work. Earnest Money deposited at the time of tenders will be treated as part of the Security Deposit.

or

The successful tenderer shall permit TIFR, Hyderabad at the time of making any payment to him for work done under the contract to deduct a sum at the rate of 5% of the gross amount of each running bill till the sum along with the sum already deposited as earnest money, will amount to security deposit of 5% of the tendered value of the work. Such deductions will be made and held by TIFR by way of Security Deposit unless he has / they have deposited the amount of Security at the rate mentioned above in cash or in the form of Fixed Deposit Receipts.

In case a fixed deposit receipt of any bank is furnished by the contractor to TIFR, Hyderabad as part of the security deposit and the bank is unable to make payment against the said fixed deposit receipt, the loss caused thereby shall fall on the contractor and the contractor shall forthwith on demand furnish additional security to TIFR, Hyderabad to make good the deficit.

All compensation or the other sums of money payable by the contractor under the terms of this contract may be deducted from, or paid by the sale of a sufficient part of his security deposit or from the interest arising there from, or from any sums which may be due to or may become due to the contractor by TIFR or any account whatsoever and in the event of his Security Deposit being reduced by reason of any such deductions or sale as aforesaid, the contractor shall within 10 days make good in cash or fixed deposit receipt tendered by the State Bank of India or by



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

scheduled banks (if deposited for more than 12 months) endorsed in favor of the TIFR, HYDERABAD, any sum or sums which may have been deducted from, or raised by sale of his security deposit or any part thereof.

Security Deposit shall be initially valid up to one year from the date of completion of work. In case the time for completion of work gets enlarged, the contractor shall get the validity of Security Deposit extended to cover such enlarged time for completion of work. The Security Deposit shall be returned to the contractor, without any interest, after completion of defect liability period.

Security Deposit as deducted above can be released against Bank Guarantee issued by a Scheduled Bank on its accumulation to a minimum of Rs.5 Lakhs subject to the condition that amount of such Bank Guarantee, except last one, shall not be less than Rs.5 Lakhs. Bank Guarantee should be submitted which will be valid upto the expiry of defect liability period.

6. Acceptance of Tender: The competent authority, on behalf of TIFR, Hyderabad does not bind itself to accept the lowest or any other tender, and reserves to himself the authority to reject any or all the tenders received, without assignment of any reason. All tenders, in which any of the prescribed conditions is not fulfilled or any condition, including that of conditional rebates, is put forth by the tenderer, shall be summarily rejected.

The Competent Authority, on behalf of TIFR, Hyderabad reserves to itself the right of accepting the whole or any part of the tender and the tenderer shall be bound to perform the same at the rates quoted. The officer inviting tenders shall have the right of rejecting all or any of the tenders and will not be bound to accept the lowest tender or any other tender.

7. Validity of Tender: The tender for the work shall remain open for acceptance for a period of 75 days from the last date of submission of tenders. If any tenderer withdraws his tender before the said period, or before issue of Letter of Intent, whichever is earlier, or makes any modifications in the terms and conditions of the tender which are not acceptable to the Department, then TIFR, Hyderabad shall, without prejudice to any other right or remedy, be at liberty to forfeit 50% of the said earnest money absolutely. Further the tenderer shall not be allowed to participate in the retendering process of the work.

8. Levy / Taxes payable by contractor:

i. GST or any other tax on materials and services in respect of this contract shall be payable by the contractor and TIFR shall not entertain any claim whatsoever in this respect.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

ii. The contractor shall deposit royalty and obtain necessary permits as required for supply of the sand, aggregate, stone etc. from local authorities.

9. Deduction of Income Tax : As per Section 194-C of Income tax Act 1961, as amended by letter No. 275/9/72/9-TJ (Circular No. 86) dated 19.5.72 and No. 275/14/91-IT (B) (Circular No. 593) dated 5.2.91, received from Ministry of Finance, Department of Revenue, Central Board of Direct Taxes, New Delhi, the Income tax @ 2% and Surcharge thereon @12% (or any other amended rate by Ministry of Finance from time to time), of the gross value of the work done will be recovered from the bills. A certificate for the amount recovered will be issued by the Department.

10. Site visit by the tenderer before tendering: Tenderers are advised to inspect and examine the site and its surroundings during working hours and satisfy themselves before submitting their tenders as to the nature of the ground and subsoil (so far as is practicable), the form and nature of the site, the means of access to the site, the accommodation they may require and in general shall themselves obtain all necessary information as to risks, contingencies and other circumstances which may influence or affect their tender. A tenderer shall be deemed to have full knowledge of the site whether he inspects it or not and no extra charges consequent on any misunderstanding or otherwise shall be allowed.

11. Signing of Tender and receipts for payments: In the event of the tender being submitted by a firm, it must be signed separately by each partner thereof or in the event of the absence of any partner, it must be signed on his behalf by a person holding a power-of-attorney authorizing him to do so, such power of attorney to be produced with the tender, and it must disclose that the firm is duly registered under the Indian Partnership Act-1952. Receipts for payments made on account of work, when executed by a firm, must also be signed by all the partners, except where contractors are described in their tender as a firm, in which case the receipts must be signed in the name of the firm by one of the partners, or by some other person having due authority to give effectual receipts for the firm.

12. Tenderer's responsibilities: The tenderer shall be responsible for arranging and maintaining at his own cost all materials, tools & plants, facilities for workers and all other services required for executing the work unless otherwise specifically provided for in the contract documents. Submission of a tender by a tenderer implies that they have read this notice & all other contract documents, and has made himself aware of the scope & specifications of the work to be done and local conditions and factors having a bearing on the execution of the work.

13. Signing of contract: The Notice Inviting Tender shall form a part of the contract document. The successful tenderer / contractor, on acceptance of his tender by the Accepting Authority, shall, within 15 days from the stipulated date of start of the work, sign the contract consisting of:



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

the Notice Inviting Tender, all the documents including all conditions, specifications and drawings, if any, forms the tender as issued at the time of invitation of tender and acceptance thereof together with any correspondence leading thereto.

14.Canvassing, either directly or indirectly, in connection with the tenders is strictly prohibited and the tenders submitted by the contractors who resort to canvassing will be liable to rejection and may be barred from future participation in TIFR works.

Head-Technical Services
For and on behalf of TIFR, Hyderabad



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

SECTION-IV

GENERAL CONDITIONS OF CONTRACT

1. Definition of Terms:

- 1.1. In constructing these general conditions and the specifications the following works shall have the meanings herein assigned to them unless there is something in the subject or context inconsistent with such construction.
- 1.2. The 'Purchaser' shall mean Tata Institute of Fundamental Research- -Hyderabad, Tata Institute of Fundamental Research, 36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad 500046 and shall include the Purchaser's heirs, successors and assigns.
- 1.3. The term 'Engineer In-Charge' and 'Engineer' shall mean Engineer In-Charge, TIFR- Hyderabad or some other person for the time being or from time to time duly appointed in writing by the Purchaser to act as Engineer In-Charge for the purpose of the Contract or in default of such appointment the Purchaser.
- 1.4. The term 'Contractor'/'Supplier'/'Bidder'/'Vendor' shall mean the Bidder whose tender has been accepted by the Owner and shall include the Bidder's heirs, successors and assigns approved by the Purchaser:
- 1.5. The term 'Sub-Contractor' shall mean the firm or persons named in the contract for any art of the work or any person to whom any part of the work has been sublet with the consent in writing of the Engineer In-Charge and shall include his heirs, successors and assigns approved by the Purchaser.
- 1.6. The Term 'Inspector' shall mean any person appointed by or on behalf of the Purchaser to inspect supplies, stores or work under the contract or any person deputed by the Inspector for the purpose.
- 1.7. The term 'Particulars' shall mean, the following :
 - 1.7.1. Specifications
 - 1.7.2. Drawing (ANNEXURE-IV)
 - 1.7.3. Sealed Pattern denoting a pattern sealed and signed by the Inspector.
 - 1.7.4. Proprietary make denoting the product of an individual firm.
 - 1.7.5. Any other details governing the construction, manufacture and/or supply as existing for the contract.
- 1.8. The term 'Specification' shall mean the specifications annexed to or issued with these Conditions of Contract.
- 1.9. The term 'Site' shall mean the place or places at which the Equipment is to be delivered or work done by the Contractor; and shall include, where applicable, the lands and buildings upon or in which the works are to be executed and shall also include the place or places at which fabrication and other work is being carried out by the Contractor.
- 1.10. 'Electrical Equipment', 'Stores', 'Work' or 'Works' shall mean and include equipment and materials to be provided and work to be done by the Contractor under the Contract.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

- 1.11. The 'Contract' shall mean acceptance of the work order placed on contractor/supplier under section (2) of these conditions and shall include these conditions of Contract, Specifications, Schedule, Drawing, Letter of Intent of the Purchaser and any subsequent amendments mutually agreed upon.
- 1.12. 'Tests on Completion' shall mean such tests which are prescribed by the specifications or have been mutually agreed to between the Contractor/Supplier and the Purchaser to be made before the equipment is taken over by the Purchaser.
- 1.13. 'Writing' shall include any manuscript, typewritten or printed statement under or over signature or seal as the case may be. Words importing 'person' shall include firms, companies, corporations and association of individuals whether incorporated or not.
- 1.14. Words importing singular shall also include plural and vice versa where context requires.
- 1.15. Bidders are advised to visit and inspect the work-site to make themselves fully conversant with the site conditions and nature of work. Any claim by them after the opening of bids on account of themselves being unaware of any site condition shall not be entertained.

2. Contract

Contractor/Supplier/Manufacturer should send their acceptance letter on receipt of 'Letter of Intent' or 'Work Order' or 'Purchase Order' within the stipulated period. On expiry of said period or exorbitant delay in commencing or executing the work, the Purchaser shall not be liable to any claim from the Contractor/ Supplier for work entrusted to and may revoke the contract.

3. Work at Site

- 3.1. Access to the works shall be allowed only to the Contractor/Supplier, Sub-Contractors or his duly appointed representatives. The Contractor/ Supplier shall not object to the execution of other works by other contractors or tradesmen and shall afford them every facility for execution of their several works simultaneously with his own.
- 3.2. Work at the Purchaser's premises shall be carried out at such time as the Purchaser may approve but the Purchaser shall give the Contractor/ Supplier all reasonable facilities for the same. The Contractor/Supplier shall provide sufficient fencing, notice boards etc. to guard the works and warn the public.
- 3.3. The Contractor shall obey Central, Local and State regulations and enactments pertaining to workmen and labor and the Engineer In-Charge shall have the right to enquire into and decide all complaints on such matters. The Contractor should comply with the Minimum Wages Act and should also ensure that safe practices are followed by his people at site.
- 3.4. The contractor should follow safety precautions and maintain safety PPE's to their workmen throughout the project. Penalty will be imposed by TIFRH if violation of safety precautions.

4. Delays

The Contractor/Supplier shall not be entitled to any compensation for any loss suffered by him on account of delays in commencing or executing the work, whatever the cause for such delays may



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

be, including delays in procuring Government controlled or other materials and delay in obtaining instructions and decisions from the Engineer In-Charge.

5. Taking Over

The equipment when erected at site shall be deemed to have been taken over by the Purchaser when the Engineer In-Charge will have certified in writing that the equipment has fulfilled the contract conditions.

6. Extension of Time

If the Contractor/Supplier is delayed in the progress of work by changes ordered in the work, or by any cause, which the Engineer In-Charge shall decide to justify the delay, then the time of completion shall be extended by a reasonable time. In this regard, the Contractor shall maintain a proper hindrance register and record all such events with due signature of E-I-C on occurrence of such instances for seeking extension of time. However, no such extension shall be allowed unless requested for extension is made in writing by the Contractor/Supplier to the Engineer In-Charge within 15 days from the date of occurrence of the delay.

7. Liquidated Damages

- 7.1. For all delays, which do not merit any extension of time, the Contractor/ Supplier shall attract 1% penalty per week for the first 4 weeks of delay and 2% penalty per week for the next 4 weeks of the total contract value. The amount of liquidated damages shall be recoverable from the payment due to the Contractor/Supplier up to maximum of 10% of value of contract.
- 7.2. The deduction of liquidated damages shall not, however, absolve the Contractor/Supplier of his responsibility and obligations under the contract to complete the work in its entirety and shall also be without prejudice to action by the Purchaser under clause:
- 7.3. 'Termination of Contract by the Purchaser'. After that the same shall be completed by the Purchaser at the Contractor's/Supplier's risk and cost.

8. Other Damages:

- 8.1. The Contractor/Supplier/Manufacturer shall be responsible for all injury to persons, animals or things and for all damage to the works, structure of, and decorative work in the property which may arise from operation or neglect of himself or any of his Subcontractor or of his or Sub-Contractor's employees, whether such injury or damage may arise from carelessness, accident or any other cause whatever in any way connected with the carrying out of this contract. This clause shall be held to include any damage to buildings, whether immediately adjacent or otherwise, any damage to roads, streets, foot paths, as well as all damage caused to the works forming the subject of this contract by frost or other inclemency of weather. The Contractor/Supplier shall indemnify the



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

Purchaser and hold him harmless in respect of all and any expenses on property as aforesaid and also in respect of any claim made in respect of injury or damage under any acts of Government or otherwise and also in respect of any award of compensation or damages consequent upon such claim. Contractor shall furnish necessary insurance documents (Contractor All Risk Policy) taken for the site before commencement of work.

8.2.The Contractor/Supplier/Manufacturer shall reinstate all damage of every sort mentioned in this clause, so as to deliver up the whole of the contract works complete and perfect in every respect and so as to make good or otherwise satisfy all claims for damage to the property of the Owner/third parties.

8.3.The Contractor/Supplier/Manufacturer shall indemnify the Purchaser against all claims which may be made against the Purchaser, by any member of the public or other party, in respect of anything which may arise in respect of the works or in consequence thereof and shall, at his own expense, effect and maintain, until the work has been 'Taken Over' under clause 5.

8.4.The Contractor/Supplier/Manufacturer shall also indemnify the Purchaser against all claims which may be made upon the Purchaser whether under the Workmen's Compensation Act or any other statute in force during the currency of this contract or at common law in respect of any employee of the Contractor/Supplier or of any of his sub-contractor and shall at his own expense effect and maintain until the work has been 'Taken Over', with an approved office. Contractor shall furnish a copy of the labor license before commencement of work. If the aforesaid are not applicable contractor should furnish declaration to this effect and shall indemnify TIFR-Hyderabad, Hyderabad for violation of any such compliances.

8.5.The Purchaser, with the concurrence of the Engineer In-Charge, shall be at liberty and is hereby empowered to deduct the amount of any damages compensation costs, charges and expenses arising or accruing from or in respect of any such claims or damages from any sums due to or become due to the Contractor/Supplier.

9. Guarantee and Defects Liability Period:

9.1.The Contractor/Supplier/Manufacturer shall guarantee that all equipment shall be free from any defect due to the defective materials and bad workmanship and that the equipment shall operate satisfactorily and that the performance and efficiencies of the equipment shall be not less than the guaranteed values. The guarantee shall be valid for a period of 12 months after the date of commissioning as certified by the Engineer In-Charge. Any parts found defective shall be replaced free of all costs by the Contractor/Supplier. The services of the Contractor's/Supplier's personnel if requisitioned during this period for such work shall be made available free of any cost to the Purchaser.

9.2.If the defects are not remedied within a reasonable time, the Purchaser may proceed to do so at the Contractor's/Supplier's risk and expense without prejudice to any other rights.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

10. Terms of Payment

The contractor will be paid only Two Running Account (RA) Bill and Final Bill considering the progress of works based on measurement of works completed. The contractor shall submit the bills for payments along with a detailed statement showing the actual works carried out under different heads of items in the format specified by TIFR-, Hyderabad. Minimum value of the work for interim payment shall be 35% of the work order value.

10.1 BILL FORMAT

Tender Item No.	Description of Items (At least 2 lines)	Unit	Tender Quantity	Executed Quantity	Rate	%work done	Amount

NOTE: All quantities in the bill should be cumulative.

All measurements should be in the order of tender sequence and should be recorded in the measurement book. The Measurement should be strictly in the below mentioned format only.

10.2 MEASUREMENT FORMAT

Tender Item No.	Description of Item & Location against each Measurement taken	Nos.	Length	Width	Height	Qty.	Remarks

The works which have been certified for running bills will also be verified along with the final bill and any defects found need to be replaced / rectified by the contractor at his cost. Till the time, the site is handed over in full, it is the contractor's liability to safeguard the works done and completed at site. The Progress of work should not be affected in any way quoting the reason of non-availability of funds / materials / releasing of Running bill. The liability of the contractor is to



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

complete all works in his scope in the scheduled time as per the terms of contract and will not relieve the contractors from his obligations once the Running bill is paid / kept pending

10.3 Final Payment

Payments of Final bill shall be made after deduction of security deposit /Performance guarantee as specified. The Security Deposit / Performance guarantee, shall be refunded on expiry of the Defects Liability Period after rectifying all defects to the satisfaction of the TIFR-Hyderabad/E.I.C. The acceptance of payment of the final bill by the Contractor would indicate that he would have no further claim in respect of the work executed.

11. Special conditions of Contract governing supplies of the Equipment of this Tender:

11.1.Scope:

- 11.1.1. This specification covers the supply of material as per the enclosed details and quantities and supervision of erection/installation, testing and commissioning of the material.
- 11.1.2. The Contractor/Manufacturer/Supplier shall quote for all the materials along with accessories as mentioned in the enquiry.
- 11.1.3. All the supply shall be in accordance with relevant I.S. Specifications and recognized standards.

11.2. Inspection & Testing and commissioning of Material:

- 11.2.1. Contractor/Manufacturer/Supplier shall submit the lists of Type Tests and Routine Tests to be conducted on the material in the Technical Data Sheet.
- 11.2.2. All the materials shall be tested at factory as per IS Specifications of material by Purchaser's Engineer In-Charge/Engineers before dispatch at the cost of Contractor/Manufacturer/Supplier.
- 11.2.3. Contractor/Manufacturer/Supplier shall inform the concerned Engineer In-Charge for inspection and testing in accordance and fix up a suitable date for the same.

11.3.Test Certificates:

Contractor/Manufacturer/Supplier shall submit the Test Certificates of all materials.

11.4. Taxes & Duty:

- 11.4.1. Contractor/Manufacturer/Supplier shall quote the basic price of material. Excise Duty, Custom Duty, Sales Tax, GST, Octroi, Delivery Charges, Transit Insurance and/or any other charges, if any, must be indicated separately.
- 11.4.2. TIFR being a research institute of Govt. of India, is eligible for Excise Duty Exemption on equipment supplies. Necessary exemption certificate will be provided by TIFR.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

- 11.4.3. Transit Insurance: The Transit Insurance from the point of dispatch to the site of erection shall be in the scope of Supplier and the cost shall be indicated separately.

11.5. Delivery of Material:

- 11.5.1. The Contractor/Manufacturer/Supplier shall be held responsible for loading of all equipment and for the stores being sufficiently and properly packed for transport by rail, road, sea or air so as to ensure their being free from any loss or damage on arrival at destination. The packing and marking of packages shall be done by and at the expenses of Manufacturer/Supplier. Each package shall contain a packing note quoting purchase order number and detail of the contents.
- 11.5.2. All the materials must be delivered at site i.e. Hyderabad - TIFR at 36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad-500046. The unloading and positioning of all equipment at the designated locations specified by the Engineer In-Charge shall be in the scope of the Supplier. The Supplier shall arrange for handling equipment, labour for rigging, etc. as required.
- 11.5.3. Material must be delivered at site in all respects as mentioned in the Purchase Order.

11.6. Guarantee:

If during the period of guarantee any fault or defect arises, the material shall be replaced/repared immediately free of cost, as well as any replacement of accessories required shall be done free of cost.

11.7. Mistake in Drawing:

The Contractor/Supplier shall be responsible for and shall pay for any alterations in works due to any discrepancies, errors or omissions the drawings or other particulars supplied by him whether such drawings or particulars have been approved by the Purchaser or not.

11.8. Responsibility for Completeness:

Any fittings or accessories which may not be specifically mentioned in the specifications but which are usual or necessary are to be provided by the Contractor/Supplier without extra charge and the equipment must be complete in all details.

11.9. Extra/Deviation items & Variations in quantity

TIFR-Hyderabad has the right to omit/delete any of the items and also increase/decrease the quantities mentioned in the tender. No claim or any compensation in this regard will be

accepted or paid to the contractor. However, if any new /additional items/deviated items are to be executed, the contractor is bound to execute such items with prior approval from TIFR-Hyderabad after furnishing the proper rate analysis for such extra/deviated items.

11.10.Rejection of Defective Equipment:

- 11.10.1. If the equipment after the acceptance thereof is discovered to be defective, notwithstanding that such defects could have been discovered at the time of inspection or found to have failed to fulfill the requirements of the contract or developed defects after the erection within a period of 12 months from the date of erection, even if such erection is done by the Purchaser, he shall be entitled to give a notice on the Contractor/Supplier setting forth details of such defects or failure and the Contractor/Supplier shall, provided such notice is given within a period of 14 months from the date of such erection or acceptance, forthwith make the defective equipment good or alter the same to make it comply with the requirements of the contract at his own cost and further if in the opinion of the Purchaser, the defects are of such a nature that the defects cannot be made good or required without impairing the efficiency or workability of the equipment or if in the opinion of the Purchaser the Equipment cannot be repaired or altered to make it comply with the requirements of the Contract, the Contractor/Supplier shall, provided a notice given by the Purchaser in this behalf within a period of 14 months from the date of erection or acceptance thereof, remove and replace the same with the equipment conforming to the stipulated particulars, in all respects at the Contractor's/Supplier's own cost. Should he fail to do so within a reasonable time, the Purchaser may reject and replace, at the cost of the Contractor/Supplier, with equipment of the same particulars or if equipment conforming to the stipulated particulars are not in the opinion of the Purchaser readily procurable, such opinion being final, then with the nearest substitutes.
- 11.10.2. In the event of such rejection the Purchaser shall be entitled to use the Equipment in a reasonable and proper manner for a time reasonably sufficient to enable him to obtain replacement equipment as herein before provided.

11.11.Inspection and Final Tests:

All tests necessary to ensure that the Equipment complies with the particulars and guarantee shall be carried out at such place or places as may be determined by the Inspector. Should, however, it be necessary for the final test as to performance or guarantee to be held over until the Equipment is erected at site they shall be carried out within one month of completion of erection.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

11.12.Intimation about Delivery:

If the Purchaser shall have notified the Contractor/Supplier in writing that the former is not ready to take delivery, no equipment or materials shall be forwarded until an intimation in writing shall have been given to the Contractor/Supplier by the Purchaser that he is ready to take delivery.

11.13.Delay in erection:

Wherever erection of an equipment or machinery is the responsibility of the Contractor/Supplier as a term of the contract and in case the Contractor fails to carry out the erection as and when called upon as to do within the period specified by the Purchaser, the Purchaser shall have right to get the erection done through any source of his choice. In such an event, the Contractor/Supplier shall be liable to bear any additional expenditure that the Purchaser may incur towards erection. The Contractor/Supplier shall, however not be entitled to any gain due to such an action by the Purchaser.

11.14.Definition of Equipment:

The work 'Equipment' wherever, it appears in these 'Special Conditions of Contract' governing supplier of Equipment in this Tender shall mean all switchgears, panels, etc. or parts thereof or what the Contractor/Supplier agrees to supply under Contract as specified in the work order.

11.15.Force Majeure:

Normally Force Majeure shall cover only acts of God, fire, wars, strike, riots and civil commotion, floods, epidemic, quarantine related strikes, freight embargoes, etc. The contractor shall not be liable for any liquidated damages for delay or any failure to perform the contract arising out of Force Majeure conditions, provided that the contractor shall within ten days from the beginning of such delay notify the department in writing the cause of delay along with convincing supporting evidence. The department once convinced and accepted the reason may extend the supply completion period by a suitable / reasonable margin.

11.16.Termination of Contract by the Purchaser:

- 11.16.1. If the Contractor/Supplier commits any 'Act of Insolvency' or shall be adjudged an Insolvent or shall have an order for compulsory winding up made against him or pass effective resolution for winding up voluntarily, or if the Contractor/Supplier shall suffer any payment under this contract to be attached by or on behalf of any of the creditors of the Contractor/ Supplier, or shall

assign the Contract without the prior consent in writing of the Engineer In-Charge, or shall charge or encumber this Contract or any payments due or which may become due to the Contractor/Supplier there under, or if the Engineer In-Charge shall certify in writing to the Purchaser that the Contractor/Supplier –

- 11.16.1.1. has abandoned the Contract, or
 - 11.16.1.2. has failed to commence the works, or has without any lawful excuse these conditions suspended the progress of the works for seven days after receiving from the Engineer In-Charge written notice to proceed, or
 - 11.16.1.3. has failed to proceed with the work with such due diligence and failed to make such due progress as would enable the works to be completed in accordance with the approved programme of work,, or
 - 11.16.1.4. has failed to remove materials from the site or to pull down and replace work for seven days after receiving from the Engineer In-Charge written notice that the said materials or work were condemned and rejected by the Engineer In-Charge under these conditions, or
 - 11.16.1.5. has neglected or failed persistently to observe and perform all or any of the acts matters or things by this contract to be observed and performed by the Contractor for seven days after written notice shall have been given to the Contractor/ Supplier requiring the Contractor/Supplier to observe or perform the same, or
 - 11.16.1.6. has to the detriment of good workmanship or in defiance of the Engineer In-Charge's instructions to the contrary sub-let any part of the contract, then and in any of the above said causes, the Purchaser with the written consent of the Engineer In-Charge may, notwithstanding any previous waiver, after giving seven days' notice in writing under the provisions of this clause to the Contractor/Supplier, determine the contract but without prejudice to the powers of the Engineer In- Charge or the obligations and liabilities of the Contract, the whole of which shall continue to be in force as if the contract has not been so determined and as if the work subsequently executed has been executed by and on behalf of the Contractor/ Supplier.
- 11.16.2. After the issue of such notice, the Contractor/Supplier shall not be at liberty to remove from site any equipment, tools and materials belonging to him which shall have been placed thereon for the purpose of the works and the Purchaser shall have lien upon such equipment, tools or materials to subsist from the date of such notice and until the notice shall have been complied with.

- 11.16.3. If the Contractor/Supplier shall fail to comply with the requirements of said notice for seven days after such notice has been given, the Purchaser shall have the power to enter upon and take possession of the works and site and all equipment, tools and materials thereon, and to engage any other person, firm or agency to complete the works, utilizing the equipment, tools and materials to the extent possible. The Purchaser shall not in any way be responsible for damage or loss of the tools, equipment and materials and the Contractor/Supplier shall not have any compensation therefore.
- 11.16.4. Upon completion of the works, the Engineer In-Charge shall certify the amount of expenditure properly incurred consequent on and incidental to the default of the Contractor/Supplier as aforesaid and such amount shall be deducted from the payments due to the Contractor/Supplier, including the Security Deposit. If the said amount exceeds the payment due to the Contractor/Supplier, the Purchaser shall be at liberty to dispose off any of the Contractor's/Supplier's materials, tools or equipment and apply the proceeds for the payments due from the Contractor/Supplier and recover the balance by process of law.
- 11.16.5. After the works have been completed after the amounts due to the Contractor/Supplier, the Engineer In-Charge shall give notice in writing to the Contractor/Supplier to remove the surplus equipment and material from site. If such equipment and materials are not removed within a period of 14 days after such notice, the Purchaser shall have the power to remove and sell the same holding the proceeds less the cost of removal and sale, to the credit of the Contractor/Supplier. The Purchaser shall not be responsible for any loss sustained by the Contractor/Supplier from the sale of the equipment and material.

12. Contractor's Representative:

The Contractor/Supplier shall employ at least one qualified representative (i.e. Hvac supervisory License with minimum 3 years of experience of similar works as stipulated by TIFR- Hyderabad in the work order) whose name shall have previously been communicated in writing to the Engineer In-Charge and approved by him to supervise the erection. Any written order or instructions given to the representative shall be deemed to have been given to the Contractor/Supplier. The Engineer In-Charge shall be at liberty to object to any particular representative/or any persons employed by the Contractor/Supplier on the work and the Contractor/Supplier shall remove the person objected to, on the receipt of the Engineer In-Charge, in writing, a request requiring him to do so and shall provide in his place another competent representative acceptable to the Engineer In-Charge.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

The Contractor's/Supplier's representative shall be a qualified electrical/ mechanical engineer possessing adequate site experience in similar nature of works.

13. Completion Time:

Unless otherwise agreed in writing between the Purchaser and the Contractor/Supplier, the work contract shall be completed within the stipulated period mentioned elsewhere in this tender document from the date of Work/Purchase Order issued to Contractor/Supplier by the Purchaser.

14. Delivery of Material at Site:

The Contractor/Supplier/Manufacturer shall arrange for safe transit and delivery of material at site and unloading the material at site.

15. Validity of Tender:

The quotation should be valid for 75 days after opening of the Part—I: Technical Bids.

16. Measurements:

All joint measurements of quantities shall be done by the Contractor at his own cost in the presence of the Engineer In-Charge or any authorized person deputed by him who will certify the routes, length and quantities etc. for the purpose of determination of the amount payable.

17. Spare Parts & Manuals:

Manufacturer/Contractor/Supplier should submit operation, maintenance and spare part list and manuals for all equipment.

18. Training:

Manufacturer/Contractor/Supplier should provide training for operation and maintenance free of cost for equipment supplied.

19. Special Instruction for bidding process

This tender is a two part tender. The Part-I: Technical Bid and Part-II: Financial Bid. Bidders shall seal each bid separately with a clear label on the envelope about its content. Both the bids should be submitted in a single drop two cover method. Any pricing details must not appear in the Part-I: Technical Bid.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

20. Drawings and Documentation:

Contractor should make and submit the drawing as per the site conditions and take approval from EIC. As-built drawings as specified in this technical specifications shall be submitted by the Contractor.

21. Permissions and Approvals:

All statutory permissions and approvals from Electricity authority as may be required for commissioning of the entire system shall be carried out by the contractor. All necessary documentation for obtaining such permissions and approvals shall be done by the contractor. Purchaser shall assist in providing required declarations. Statutory fees shall be paid by the purchaser.

22. Guarantee:

The equipment shall be guaranteed against all design and manufacturing defects, poor workmanship etc. for a period of 12 months from the date of commissioning or 15 months from the date of supply, whichever is earlier. Any defects discovered during this period shall be rectified by the vendor free of cost to the purchaser.



SECTION-V

TECHNICAL SPECIFICATIONS

TECHNICAL SPECIFICATIONS

1.0 DUCTING:

1.1 GSS DUCTING WITH MS ANGLE FRAMES:

GI sheets shall be as per IS 277 – 120 Grade. Fabrication shall be as per SMACNA 2005. Ducting shall be factory fabricated and delivered at site. Thickness of the sheet and type connector shall be as per the following table.

Duct Dimension (mm)	500 Pa	
	Sheet Gauge	Connector
0 - 450	26	TDF
451 - 750	26	TDF
751 - 900	24	TDF
901 - 1000	22	TDF
1001 - 1200	22	Slip-on
1201 - 1300	20	Slip-on
1301 - 1500	20	Slip-on
1501 - 1800	20	Slip-on
1801 - 2100	18	Slip-on
2101 - 2200	18	Slip-on
2201 - 2400	18	Slip-on
2401 - 2700	16	Slip-on

Duct Dimension (mm)	1000 Pa	
	Sheet Gauge	Connector
0 - 450	24	MS angle frame - 40x40x3 mm
451 - 750	24	MS angle frame- 40x40x3 mm
751 - 900	22	MS angle frame- 40x40x3 mm
901 - 1000	20	MS angle frame- 40x40x3 mm
1001 - 1200	20	MS angle frame- 40x40x3 mm
1201 - 1300	18	MS angle frame- 40x40x6 mm



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

1301 - 1500	18	MS angle frame- 40x40x6 mm
1501 - 1800	18	MS angle frame- 40x40x6 mm
1801 - 2100	16	MS angle frame- 40x40x6 mm
2101 - 2200	16	MS angle frame- 40x40x6 mm
2201 - 2400	16	MS angle frame- 40x40x6 mm
2401 - 2700	16	MS angle frame- 40x40x6 mm

For GSS ducting, rivets shall be of MS. The distance between the rivets shall not exceed 100mm. The distance between bolt & nuts shall not exceed 100mm.

All bolts, nuts & washers shall be of GI. Bolt & nuts shall provide with both sides washers. Good quality self-adhesive rubber gaskets with 5 mm thickness shall be used.

Ducting shall be supported on MS pre painted 'L' shaped brackets with required cross bracing for all the ducts which are running along the wall. All the MS supports shall be painted with one coat of red-oxide and two coats of black enamel paint. For hanging ducts supported from the true ceiling, GI full threaded rod and slotted angle shall be used as per the following table.

S. No.	Duct Size	Thickness of formed channel	Gauge	Rod dia.	Anchor Fastener
1	Up to 500mm	1.0mm	20	8 mm	M 8
2	501 – 1000mm	1.5 mm	16	8 mm	M 8
3	1001 – 1500mm	2.0mm	14	10 mm	M 10
4	Above 1500mm	3.0mm	14	12 mm	M 12

Anchor fasteners made shall be Hilti / Fischer.

Ducting supports shall be provided at every 2400mm distance. Ducting supports shall be provided on both sides of the wall / partition when it is passing through the wall / partition. Ducting shall not be supported on the wall or false ceiling. Duct support shall not be sagging. Proper care should be taken to avoid duct leakages. Sealant shall be used if required. Vanes in elbows and collar take off shall be provided. Sealant shall be applied to all transverse joints and longitudinal joints for ducting. Measurements for the ducting shall be taken at the center line.

Duct sleeves made of 18 G sheet shall be provided at wall crossings. MS angle frames shall be provided on the both sides and at the middle to take the weight of the wall. The sleeve size shall be 50mm more than duct size. Duct shall be supported on both sides of the wall / sleeve.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

Gap between the sleeve and duct shall be filled with fiber glass material tightly around the duct. This needs to be done by an HVAC contractor.

On both sides of the wall, fire sealant shall be applied on the surface. This work will be part of civil work / interior work.

Each duct piece shall not be longer than 4' and shall be smaller wherever required as per the drawing and as per the site conditions. Full elbows / partial elbows shall be as required.

Ducting shall be subjected to pressure testing at designed pressure as per SMACNA. Necessary opening of ducts, taking of take offs, providing dummies, etc. shall be done before conducting the duct pressure test.

The air distribution system shall be tested and balanced so that the requisite temperature and air flow are maintained throughout the space to be air-conditioned or ventilated. The CONTRACTOR shall provide all instruments required for testing and balancing of air distribution system. Complete air balance report shall be submitted for approval.

1.2.AHU PLENUMS:

50 mm thick double skin panel factory fabricated plenum. Plenum shall be made of outer skin 22 G powder coated G.I sheet and inner skin shall be of 22 G plain GSS with aluminum extrusions. Density of the puff panel shall be 48 kg / cub mt. The construction of the plenum shall be similar to AHU. Necessary cutout with collar shall be made to connect the branch ducts. Aluminum extractions shall be of thermal break and with internal coving. Plenum also shall be pressure tested at site for 1000 Pascal's. Plenum shall have internal stiffeners to withstand the pressure. Plenum surfaces shall not bulge under 1000 Pascal's. Plenum shall be supported with MS channels and threaded rods. Plenum shall not condensate during extreme weather conditions.

1.3.VOLUME CONTROL DAMPERS:

Volume control dampers shall be made out of 18G/1.25 mm thickness galvanized steel sheet frame with 20G/1.0 mm thick blade. Blades should be double skinned aluminum aerofoil construction and opposed blades should be at 50mm pitch centers. The blades should be mounted in nylon bushes operated by an interior wheel gear system. The operating lever or knob shall have locking arrangement and markings of various positions including open and closed position. VCD shall be low leakage type and volume control of 0-100% complete with neoprene rubber gasket, nuts, bolts, screws, linkages, flanges etc.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

1.4.MOTORIZED FIRE DAMPERS:

Fire dampers shall be rated for at least 90 minutes @ 250 deg. C fire rating as per UL555 tested by CBRI India.

Fire damper & blades shall be one piece folded high strength 16 gage galvanized steel construction with extended sleeves. All dampers ≥ 2000 mm width shall be fabricated in multiple sections. The damper rods shall be MS epoxy coated with bronze bushes at one end and locking quadrant with damper position indicator at the other end. The damper rods shall extend beyond the enclosure frame and insulation wherein provided.

Each damper shall be provided with its own control panel, mounted on the wall and Suitable for 240 VAC supply. This control panel shall be suitable for spring return Actuator and shall have at least the following features:

- ☐ Potential free contacts for AHU fan ON/ off and remote alarm indication.
- ☐ Accept signal from external smoke / fire detection system for tripping the electrical actuator. Damper shall open automatically when the fault signal is removed.
- ☐ Test and reset facility.
- ☐ Indicating lights / contacts to indicate the following status:
 - Power Supply On
 - Alarm
 - Damper open and close position.

The torque rating of the actuator shall exceed at least by 15% over torque required to open / close the damper. Shall have manual override facility. The selection of actuator size shall be the responsibility of the manufacturer/Contractor. Shall have a reset push button, push button for manual running of actuator for periodic inspection, auxiliary contacts 24V & 230 V, contact points to receive signal from smoke detector / fire alarm panel etc. should be provided.

The fire dampers shall be made of 16G GI of suitable thickness of body and blades for 90 mt. fire rating. Actuator shall be installed outside / inside the damper as required. Fire dampers with actuators shall be UL rated. Cabling within the AHU room shall be included in the scope. Actuator shall not obstruct the wall closing. Sleeve shall be

Installed in the wall before installing the fire damper in the sleeve. All the gaps around the sleeve shall be properly closed. The gap between the sleeve and fire damper shall be closed with fire



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

sealant. Each fire damper shall have its own control panel, temp sensor, smoke sensor and the control panel shall have provision to give signal to third party BMS for monitoring status of the fire damper. Fire damper shall be capable of taking the signal from the fire module.

Fire damper access doors shall be provided within the duct in accordance with the manufacturer's recommendation / as per the approved drawings mentioned. The access doors for dampers shall be factory fabricated double skin of size 400 x 400mm steel bolted with rubber gasket.

Fire Damper Actuator Torque shall be having 10Nm torque up to 1.0 Sqm size & 20 Nm up to 2.4 Sqm. Of the face area.

1.5.THERMAL INSULATION OF DUCT:

VCD/Motorized VCD's and Motorized Fire Dampers shall be insulated with 40 Kg. / cub. mt. density 25 mm thick. Class 'O' nitrile rubber insulation. Thermal conductivity shall be 0.04 W / m. deg. K. Insulation material shall be fixed to the VCD/Motorized VCD's and Motorized Fire Dampers with adhesive. All angle joints shall be covered with 6 inch wide insulation. All insulation joints shall be sealed with 50 mm wide self-adhesive tape recommended by the supplier of insulation. Insulation shall be finished properly around the dampers etc..25 mm thk. Class 'O' Nitrile rubber insulation for supply air ducting shall be insulated with 40 Kg. / cub. mt. density. Thermal conductivity shall be 0.04 W / m. deg. K. Insulation shall have factory laminated aluminum foil. Thickness of the aluminum foil shall be minimum 70 microns. All joints shall be sealed with self adhesive aluminum tape. 19 mm thk. Class 'O' Nitrile rubber insulation for return air ducting shall be insulated with 40 Kg. / cub. mt. density. Thermal conductivity shall be 0.04 W / m. deg. K. Insulation shall have factory laminated aluminum foil. Thickness of the aluminum foil shall be minimum 70 microns. All joints shall be sealed with self adhesive aluminum tape. Insulation measurements shall be taken over the insulation.

1.6.MS SUPPORTING STRUCTURE:

Ducting supports shall be designed to carry the weight of ducts. The drawing shall be submitted for approval for its load carrying capacity. Necessary safety appliances and safety permits shall be taken by the contractor. The painting shall be done as per the clause.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

1.7.DIFFUSERS:

The contractor shall ensure that the diffusers offered are of requisite capacity, throw and terminal velocity. Diffusers shall be fabricated from aluminum sections with powder coating. Areas shall be calculated by measuring cross-section area for air flow at discharge or capture area excluding flanges. In air diffusers, VCDs shall form part of unit prices quoted and shall not be separately measured or accounted. Framework for diffusers shall also be included in unit prices quoted.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

APPROVED MAKES

S.No.	Item	Approved Makes
1	Factory Fabricated Ducting	Ductofab/Radiant/Aswa/Zeco/Equivalent.
2	GI Sheets	SAIL / Jindal / Tata
3	Double Skin Plenum	Sagar Air / Vayhan Air/Asawa /Equivalent
4	VCD	V Star / Sagar Air /Asawa / Airmaster / Systemair/Equivalent
5	Fire Dampers	Airmaster / Systemair/Asawa /Equivalent
6	Actuator	Belimo/Siemens/Jhonson/Equivalent
7	Insulation	Armacell / K Flex / ALP Aeroflex/Equivalent
8	Diffusers	V Star / Sagar Air /Asawa / Airmaster / Systemair/Equivalent



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

SECTION-VI

ANNEXURES

ANNEXURE I

FORM OF PERFORMANCE GUARANTEE (BY BANK GUARANTEE)

1. In consideration of the TIFR-Hyderabad, Hyderabad having agreed under the terms and conditions of Letter of Intent / Agreement No..... dated..... made between and..... (Here in after..... called "the said Contractor(s)"), for the work (Here in after called "the said Letter of Intent / Agreement") having agreed to production of a irrevocable bank Guarantee for Rs..... (Rupees only), as a security / guarantee from the contractor(s) for compliance of his obligations in accordance with the terms and conditions in the said agreement, we (Indicate the name of the Bank) (hereinafter referred to as "the Bank") Here by undertake to pay to TIFR an amount not exceeding Rs. (Rs only) on demand by TIFR.
2. We..... (indicate the name of Bank) do hereby undertake to pay the amounts due and payable under this guarantee without any demur, merely on a demand from TIFR stating that the amount claimed is required to meet the recoveries due or likely to be due from the said Contractor(s). Any such demand made on the bank shall be conclusive as regards the amount due and payable by the Bank under this guarantee. However, our liability under this guarantee shall be restricted to an amount not exceeding Rs..... (Rupees..... only).
3. We, the said bank, further undertake to pay to TIFR any money so demanded notwithstanding any dispute or disputes raised by the Contractor(s) in any suit or proceeding pending before any Court or Tribunal relating thereto, our liability under this present being absolute and unequivocal. The payment made by us under this bond shall be a valid discharge of our liability for payment thereunder and the Contractor(s) shall have no claim against us for making such payment.
4. We (indicate the name of Bank) further agree that the guarantee herein contained shall remain in full force and effect during the period that would be taken for the performance of the said Agreement and that it shall continue to be enforceable till all the dues of TIFR under or by virtue of the said Agreement have been fully paid and its claims satisfied or discharged or till Engineer-in-charge on behalf of the TIFR certifies that the terms and conditions of the said Agreement have been fully and properly carried out by the said Contractor(s) and accordingly discharges this guarantee.
5. We (indicate the name of Bank) further agree with TIFR that TIFR shall have the fullest liberty without our consent and without affecting in any manner our obligations hereunder to vary any of the terms and conditions of the said Agreement or to extend time of performance by the said Contractor(s) from time to time or to postpone for any time or from time to time any of the powers exercisable by TIFR against the said Contractor(s) and to forbear or enforce any of the terms and conditions relating to the said Agreement and we shall not be relieved from our liability by reason of any such variation, or extension being granted to the said Contractor(s) or for any forbearance, act of omission on the part of TIFR or any indulgence by TIFR to the said Contractor(s) or by any such matter or thing whatsoever which under the law relating to sureties would, but for this provision, have effect of so relieving us.
6. This guarantee will not be discharged due to the change in the constitution of the Bank or the Contractor(s).
7. We..... (indicate the name of Bank) lastly undertake not to revoke this guarantee except with the previous consent of TIFR in writing.
8. This guarantee shall be valid up to, unless extended on demand. Notwithstanding anything mentioned above, our liability against this guarantee is restricted to Rs (Rupees only) and unless a claim in writing is lodged with us within six months of the date of expiry or the extended date of expiry of this guarantee, all our liabilities under this guarantee shall stand discharged.

Signed and sealed

Dated the day of..... for..... (indicate the name of Bank) *(Note: The Letter of Intent shall form part of the Agreement)



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

ANNEXURE II

UNDERTAKING BY THE TENDERER

I / We have read and examined the Tender document including terms & conditions, specifications, Schedule of quantities, drawings and designs, general rules & directions, General Conditions of Contract, Special Conditions of Contract and all relevant other documents, publications and rules referred to in the Conditions of Contract and all other contents in the tender documents for the work.

I / We, hereby tender for execution of the work specified for the TIFR-Hyderabad, Hyderabad within the time specified and in accordance in all respects with the specifications, designs, drawings and instructions in writing.

We agree to keep the tender open for seventy five (75) days from the last date of its submission and not to make any modifications in its terms and conditions. A sum of Rs..... has been deposited in cash / receipt treasury challan / deposit at call receipt of scheduled bank / fixed deposit receipt of scheduled bank / demand draft of a scheduled bank / Bank Guarantee issued by a Scheduled Bank as earnest money. If I / we, fail to furnish the prescribed performance guarantee within prescribed period, I / we agree that the said TIFR-Hyderabad, Hyderabad or its authorized officer shall without prejudice to any other right or remedy, be at liberty to forfeit the said earnest money absolutely. Further, if I / we fail to commence work as specified, I / we agree that the TIFR-Hyderabad, Hyderabad shall without prejudice to any other right or remedy available in law, be at liberty to forfeit the said earnest money and the performance guarantee absolutely, otherwise the said earnest money shall be retained by TIFR- Hyderabad, Hyderabad towards security deposit to execute all the works referred to in the tender documents upon the terms and conditions contained or referred to therein.

Further, I / We agree that in case of forfeiture of earnest money or both Earnest Money & Performance Guarantee as aforesaid, I / We shall be debarred for participation in the re-tendering process of the work.

I / We hereby declare that I / We shall treat the tender documents, drawings and other records connected with the work as secret / confidential documents and shall not communicate information derived there-from to any person other than a person to whom I / We am / are authorized to communicate the same or use the information in any manner prejudicial to the safety of the State.

Seal & Signature of Contractor Postal Address

Dated

Witness Address Occ



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

ANNEXURE-III

CERTIFICATE OF LOCAL CONTENT

*We [name of manufacturer] hereby confirm in respect of quoted item(s) that local Content is equal to or more than 50% and come under 'Class-I Local Supplier' Category. As being 'Class-I Local Supplier', we are eligible for Purchase Preference under 'Make in India' Policy vide Gol Order No.P-45021/2/2017-PP (B.E.-II) dated 15.06.2017 (subsequently revised vide orders dated 28.05.2018, 29.05.2019 and 04.06.2020)

OR

*We [name of manufacturer] hereby confirm in respect of quoted items(s) that Local Content is more than 20% but less than 50% and come under 'Class-II Local Supplier' Category.

The details of the location (s) at which the local value addition made is / are under:

1.

2.

Date:

Seal & Signature of the Bidder

NOTE:

Self-certification that the item offered meets the minimum local content (as above) giving details of the location(s) at which the local value addition is made in case the bidder wishes to avail the benefits under the make in India policy, if applicable.

In cases of procurement for a value in excess of Rs.10 crores, the local supplier shall be required to provide a certificate from the statutory auditor or cost auditor of the company (in the case of companies) or from a practicing cost accountant or practicing chartered accountant (in respect of suppliers other than companies) giving the percentage of local content to avail the benefits under the make in India policy, if applicable.




टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)


सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

ANNEXURE-IV


DUCTING LAYOUT DRAWING



SECTIONS



VIEW A-A



VIEW B-B



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

SECTION-VII

FINANCIAL BID

INVITATION OF BIDS FOR

Supply, Installation, Testing and commissioning of Air Distribution works for Petawatt Laser Facility at TIFR, Survey No. 36/P, Gopanpally (Village), Serilingampally (Mandal), Ranga Reddy Dist., Hyderabad-500046.

PART II

FINANCIAL BID



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

S.No	Description	Unit	Qty(A)	Unit Rate(B)	Total Amount(C=A*B)
1.	Supply, Installation, Testing and Commissioning of GSS ducting square / rectangular Factory Fabricated Ducting (120GSM) of thickness 0.63 mm sheet (24G) complete with gaskets, elbows, splitters, vanes, cowls, supports arrangement using GI full threaded rods and slotted rails as per drawings, air distribution specifications and requirements. Ducts are joined with iron angle frames with suitable nuts, bolts, gaskets etc., Proper care shall be taken to avoid noise and vibrations. Sleeves shall be provided at wall crossings. Ducting shall be designed for 1000 pascals ESP for supply & Return air ducting as per SMACNA-2005 & specifications. After installation of ducting and before cutting for branches/collars and before insulation, ducting shall be pressure tested at 1000 pascals as per SMACNA.	SQMTR	950		
2.	Supply, Installation, Testing and Commissioning of GSS ducting square / rectangular Factory Fabricated Ducting (120GSM) of thickness 0.80 mm sheet (22G) complete with gaskets, elbows, splitters, vanes, cowls, supports arrangement using GI full threaded rods and slotted rails as per drawings, air distribution specifications and requirements. Ducts are joined with iron angle frames with suitable nuts, bolts, gaskets etc., Proper care shall be taken to avoid noise and vibrations. Sleeves shall be provided at wall crossings. Ducting shall be designed for 1000 pascals ESP for supply & Return air ducting as per SMACNA-2005 & specifications. After installation of ducting and before cutting for branches/collars and before insulation, ducting shall be pressure tested at 1000 pascals as per SMACNA.	SQMTR	450		
3.	Supply, Installation, Testing and Commissioning of GSS ducting square / rectangular Factory Fabricated Ducting (120GSM) of thickness 1.0 mm sheet (20G) complete with gaskets, elbows, splitters, vanes, cowls, supports arrangement using GI full threaded rods and slotted rails as per drawings, air distribution specifications and requirements. Ducts are joined with iron angle frames with suitable nuts, bolts, gaskets etc., Proper care shall be taken to avoid noise and vibrations. Sleeves shall be provided at wall crossings. Ducting shall be designed for 1000 pascals ESP for supply & Return air ducting as per SMACNA-2005 &	SQMTR	450		



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
 भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
 (An Autonomous Institute of the Department of Atomic Energy,
 Government of India, and a Deemed University)
 सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

	specifications. After installation of ducting and before cutting for branches/collars and before insulation, ducting shall be pressure tested at 1000 pascals as per SMACNA.				
4.	Supply, Installation, Testing and Commissioning of GSS ducting square / rectangular Factory Fabricated Ducting (120GSM) of thickness 1.25 mm sheet (18G) complete with gaskets, elbows, splitters, vanes, cowls, supports arrangement using GI full threaded rods and slotted rails as per drawings, air distribution specifications and requirements. Ducts are joined with iron angle frames with suitable nuts, bolts, gaskets etc., Proper care shall be taken to avoid noise and vibrations. Sleeves shall be provided at wall crossings. Ducting shall be designed for 1000 pascals ESP for supply & Return air ducting as per SMACNA-2005 & specifications. After installation of ducting and before cutting for branches/collars and before insulation, ducting shall be pressure tested at 1000 pascals as per SMACNA.	SQMTR	530		
5.	Supply, Installation, Testing and Commissioning of GSS ducting square / rectangular Factory Fabricated Ducting (120GSM) of thickness 1.6 mm sheet (16G) complete with gaskets, elbows, splitters, vanes, cowls, supports arrangement using GI full threaded rods and slotted rails as per drawings, air distribution specifications and requirements. Ducts are joined with iron angle frames with suitable nuts, bolts, gaskets etc., Proper care shall be taken to avoid noise and vibrations. Sleeves shall be provided at wall crossings. Ducting shall be designed for 1000 pascals ESP for supply & Return air ducting as per SMACNA-2005 & specifications. After installation of ducting and before cutting for branches/collars and before insulation, ducting shall be pressure tested at 1000 pascals as per SMACNA.	SQMTR	610		
6.	Supply, Installation, Testing and Commissioning of 50 mm thk double skin panel factory fabricated plenum. Plenum shall be made of outer skin 22 G powder coated G.I sheet and inner skin shall be of with 22 G plain GSS with aluminum extrusions. Density of the puf panel shall be 48 kg / cub mt. Appropriate cutout with collar shall be made to connect the branch ducts. Aluminum extrusions shall be of thermal break and with internal coving. Plenum also shall be pressure tested at site for 1000 pascals. Plenum shall have internal stiffeners to withstand the pressure. Plenum surfaces shall not bulge under 1000 pascals. Plenum shall be supported with MS channels and threaded rods. Plenum shall not condensed during extreme weather conditions.	SQMTR	200		
7.	Supply, Installation, Testing and Commissioning of GSS made volume control damper with opposed blades, frame shall be made of 18G GSS and blades shall be made of 20G aluminum aerofoil low leakage type and volume control of 0-100% complete with neoprene rubber gasket, nuts, bolts, screws linkages, flanges etc.	SQMTR	25		



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
 भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
 (An Autonomous Institute of the Department of Atomic Energy,
 Government of India, and a Deemed University)
 सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

8.	Supply, Installation, Testing and Commissioning of motorized on / off GSS made volume control damper with opposed blades, frame shall be made of 18G GSS and blades shall be made of 20G aluminum aerofoil low leakage type and volume control of 0-100% complete with neoprene rubber gasket, nuts, bolts, screws linkages, flanges etc. Motorized fire dampers shall be interlocked with AHU starter / control panel. Motorized volume control dampers shall open when the AHU is in running condition and shall be closed when the AHU is in off condition.	SQMTR	15		
9.	Supply, Installation, Testing and Commissioning of suitable Actuators for Sr. No.8 motorized Volume Control Dampers	NOS	12		
10.	Supply, Installation, Testing and Commissioning of motorized fire dampers suitable 90 min @ 250 deg. C rating with sleeve, for supply and return air ducts. Dampers shall be sleeve type and suitable for wall mounting. Fire dampers shall be CBRI tested as per UL 555.	SQMTR	11		
11.	Supply, Installation, Testing and Commissioning of suitable Actuators for Sr. No.10 motorized Fire Dampers	NOS	14		
12	Supply, Installation, Testing and Commissioning of suitable Fire Damper Control Panel. Common fire damper control panels shall be given grouping fire dampers nearby. Power cable and control cable from the common control panel shall be supplied and laid to all the fire dampers. Fire damper control panel shall have ON/OFF status with LED indicators and shall have RS 485 integration to BMS. Fire damper control panel shall have provision to integrate with the fire alarm system. Control panel shall switch off the AHUs and close the fire dampers in case of fire. Fire Dampers shall be opened automatically once the fire signal is removed. Each control panel shall be suitable for 8no's fire dampers.	NOS	2		
13	Supply, Installation, Testing and Commissioning of factory fabricated fire retardant canvas cloth for connecting the AHU inlets & outlets to duct connection with 100 width GI strip, zip, nut, bolts & accessories as required. Canvas cloth with GI strip shall be ready made and shall not be hand fabricated.	RMT	60		
14	Supply, Installation, Testing and Commissioning of 25 mm thk. Class 'O' Nitrile rubber insulation for supply air ducting for the cleanroom as per the specification. Insulation shall have factory laminated aluminum foil. Thickness of the aluminum foil shall be minimum 70 microns. All joints shall be sealed with self adhesive aluminum tape.	SQMTR	1950		



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)
सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

15	Supply, Installation, Testing and Commissioning of 19 mm thk. Class 'O' Nitrile rubber insulation for return air ducting for the cleanroom as per the specification. Insulation shall have factory laminated aluminum foil. Thickness of the aluminum foil shall be minimum 70 microns. All joints shall be sealed with self adhesive aluminum tape.	SQMTR	1240		
16	Supply, Fixing, testing and commissioning of supply air and return air diffusers of powder coated aluminum with aluminum volume control dampers.	SQMTR	19.2		
17	Supply, fabrication, installation and painting with MS Channels / Angles. Cross members shall be installed across the structural beams wherever required for taking the supports for ducts. Cross members shall be welded to structural beams and shall be painted with one coat of the primer and two coats of the finish paint. Floor supports shall be provided near the AHU for the ducts wherever it is necessary.	KGS	1000		
				Sub-Total (D)	
				GST 18% (E)	
				GRAND TOTAL (D+E)	
Total Amount in Words RsOnly					

NOTE:

1. Please mention the item rate in figures and also in words.



टाटा मूलभूत अनुसंधान संस्थान
TATA INSTITUTE OF FUNDAMENTAL RESEARCH
भारत सरकार के परमाणु ऊर्जा विभाग की स्वायत्त संस्था एवं समविश्वविद्यालय
(An Autonomous Institute of the Department of Atomic Energy,
Government of India, and a Deemed University)

सर्वेक्षण संख्या 36 / पी, गोपनपल्ली गांव, सेरिलिंगमपल्ली मंडल, रंगारेड्डी जिला, हैदराबाद - 500 046
36/P, Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, Hyderabad - 500 046

-
2. Rates are all inclusive of profit, Transport, Loading & Unloading, Shifting Taxes, Etc.
 3. TIFR, Hyderabad has right to delete any of above items from scope of work or may increase/reduce quantities as per its requirement during execution of work. No claim or compensation for such deletion/increase/decrease will be accepted/paid to the contractor. Payment will be made as per actual quantities executed at tender rates.
 4. Manufacturer's warranty of respective supply items to be provided.
 5. For any above item quantity exceeding more than 10% of projected qty, contractor shall take prior approval from TIFR Engineer in writing.
 6. For any deviating items, the contractor shall take prior approval from TIFR Engineer In charge with proper rate analysis.