

बिड दस्तावेज़ / Bid Document

बिड विवरण/Bid Details	
बिड बंद होने की तारीख/समय /Bid End Date/Time	21-10-2025 18:00:00
बिड खुलने की तारीख/समय /Bid Opening Date/Time	21-10-2025 18:30:00
बिड पेशकश वैधता (बंद होने की तारीख से)/Bid Offer Validity (From End Date)	75 (Days)
मंत्रालय/राज्य का नाम/Ministry/State Name	Pmo
विभाग का नाम/Department Name	Department Of Atomic Energy
संगठन का नाम/Organisation Name	Tata Institute Of Fundamental Research Hyderabad
कार्यालय का नाम/Office Name	Hyderabad
कुल मात्रा/Total Quantity	2
वस्तु श्रेणी /Item Category	Online Ups Modular Type (Q3)
बिडर का न्यूनतम औसत वार्षिक टर्नओवर (3 वर्षों का) /Minimum Average Annual Turnover of the bidder (For 3 Years)	12 Lakh (s)
उन्हीं/समान सेवा के लिए अपेक्षित विगत अनुभव के वर्ष/Years of Past Experience Required for same/similar service	3 Year (s)
एमएसएमई के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है/MSE Exemption for Years of Experience and Turnover	No
स्टार्टअप के लिए अनुभव के वर्षों और टर्नओवर से छूट प्रदान की गई है /Startup Exemption for Years of Experience and Turnover	No
विक्रेता से मांगे गए दस्तावेज़/Document required from seller	Experience Criteria,Bidder Turnover,OEM Authorization Certificate,Additional Doc 1 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
क्या आप निविदाकारों द्वारा अपलोड किए गए दस्तावेज़ों को निविदा में भाग लेने वाले सभी निविदाकारों को दिखाना चाहते हैं? संदर्भ मेनू है/Do you want to show documents uploaded by bidders to all bidders participated in bid?	Yes (Documents submitted as part of a clarification or representation during the tender/bid process will also be displayed to other participated bidders after log in)

बिड विवरण/Bid Details	
बिड लगाने की समय सीमा स्वतः नहीं बढ़ाने के लिए आवश्यक बिड की संख्या। / Minimum number of bids required to disable automatic bid extension	3
दिनों की संख्या, जिनके लिए बिड लगाने की समय-सीमा बढ़ाई जाएगी। / Number of days for which Bid would be auto-extended	7
ऑटो एक्सटेंशन अधिकतम कितनी बार किया जाना है। / Number of Auto Extension count	1
बिड से रिवर्स नीलामी सक्रिय किया/Bid to RA enabled	No
बिड का प्रकार/Type of Bid	Two Packet Bid
प्राथमिक उत्पाद श्रेणी/Primary product category	Online Ups Modular Type
तकनीकी मूल्यांकन के दौरान तकनीकी स्पष्टीकरण हेतु अनुमत समय /Time allowed for Technical Clarifications during technical evaluation	3 Days
निरीक्षण आवश्यक (सूचीबद्ध निरीक्षण प्राधिकरण /जेम के साथ पूर्व पंजीकृत एजेंसियों द्वारा)/Inspection Required (By Empanelled Inspection Authority / Agencies pre-registered with GeM)	No
अनुमानित बिड मूल्य /Estimated Bid Value	2378009
मूल्यांकन पद्धति/Evaluation Method	Total value wise evaluation
वित्तीय दस्तावेज की आवश्यकता है / Financial Document Required	Yes
मध्यस्थता खंड/Arbitration Clause	No
सुलह खंड/Mediation Clause	No

ईएमडी विवरण/EMD Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईएमडी राशि/EMD Amount	47560

ईपीबीजी विवरण /ePBG Detail

एडवाइजरी बैंक/Advisory Bank	State Bank of India
ईपीबीजी प्रतिशत (%) /ePBG Percentage(%)	5.00
ईपीबीजी की आवश्यक अवधि (माह) /Duration of ePBG required (Months).	12

(a). जेम की शर्तों के अनुसार ईएमडी छूट के इच्छुक बिडर को संबंधित केटेगरी के लिए बिड के साथ वैध समर्थित दस्तावेज़ प्रस्तुत करने हैं। एमएसई केटेगरी के अंतर्गत केवल वस्तुओं के लिए विनिर्माता तथा सेवाओं के लिए सेवा प्रदाता ईएमडी से छूट के पात्र हैं। व्यापारियों को इस नीति के दायरे से बाहर रखा गया है।/EMD EXEMPTION: The bidder seeking EMD exemption, must submit the valid supporting document for the relevant category as per GeM GTC with the bid. Under MSE category, only manufacturers for goods and Service Providers for Services are eligible for exemption from EMD. Traders are excluded from the purview of this Policy.

(b).ईएमडी और संपादन जमानत राशि, जहां यह लागू होती है, लाभार्थी के पक्ष में होनी चाहिए। / EMD & Performance security should be in favour of Beneficiary, wherever it is applicable.

लाभार्थी /Beneficiary :

Administrative Officer

Hyderabad, Department of Atomic Energy, TATA INSTITUTE OF FUNDAMENTAL RESEARCH HYDERABAD, PMO
(Hari Prasad Desharaju)

बोली विभाजन लागू नहीं किया गया/ Bid splitting not applied.

एमआईआई खरीद वरीयता/MII Purchase Preference

एमआईआई खरीद वरीयता/MII Purchase Preference	Yes
--	-----

एमएसई खरीद वरीयता/MSE Purchase Preference

एमएसई खरीद वरीयता/MSE Purchase Preference	Yes
---	-----

1. The minimum average annual financial turnover of the bidder during the last three years, ending on 31st March of the previous financial year, should be as indicated above in the bid document. Documentary evidence in the form of certified Audited Balance Sheets of relevant periods or a certificate from the Chartered Accountant / Cost Accountant indicating the turnover details for the relevant period shall be uploaded with the bid. In case the date of constitution / incorporation of the bidder is less than 3-year-old, the average turnover in respect of the completed financial years after the date of constitution shall be taken into account for this criteria.

2. Experience Criteria: In respect of the filter applied for experience criteria, the Bidder or its OEM of the product offered in the bid {themselves or through reseller(s)} should have regularly, manufactured and supplied same or similar Category Products to any Central / State Govt Organization / PSU for number of Financial years as indicated above in the bid document before the bid opening date. Copies of relevant contracts and delivery acceptance certificates like CRAC to be submitted along with bid in support of having supplied some quantity during each of the Financial year. In case of bunch bids, the category of primary product having highest value should meet this criterion.

3. Preference to Make In India products (For bids < 200 Crore):Preference shall be given to Class 1 local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a Class 1 local supplier is denoted in the bid document. If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted. In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 dated 04.06.2020. Only Class-I and Class-II Local suppliers as per MII order dated 4.6.2020 will be eligible to bid. Non - Local suppliers as per MII order dated 04.06.2020 are not eligible to participate. However, eligible micro and small enterprises will be allowed to participate .The buyers are advised to refer the OM No.F.1/4/2021-PPD dated 18.05.2023.

[OM_No.1_4_2021_PPD_dated_18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017.

4. Purchase preference will be given to MSEs having valid Udyam Registration and whose credentials are validated online through Udyam Registration portal as defined in Public Procurement Policy for Micro and Small

Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail themselves of the Purchase preference, the bidder must be the manufacturer / OEM of the offered product on GeM. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises and hence resellers offering products manufactured by some other OEM are not eligible for any purchase preference. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service and Buyer will decide eligibility for purchase preference based on documentary evidence submitted, while evaluating the bid. If L-1 is not an MSE and MSE Seller (s) has / have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such MSE Seller shall be given opportunity to match L-1 price and contract will be awarded for 25% (selected by Buyer) percentage of total quantity. The buyers are advised to refer the OM No. F.1/4/2021-PPD dated 18.05.2023 [OM No.1 4 2021 PPD dated 18.05.2023](#) for compliance of Concurrent application of Public Procurement Policy for Micro and Small Enterprises Order, 2012 and Public Procurement (Preference to Make in India) Order, 2017. Benefits of MSE will be allowed only if seller is validated on-line in GeM profile as well as validated and approved by Buyer after evaluation of documents submitted.

5. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

Pre Bid Detail(s)

मूल्य भिन्नता खंड दस्तावेज़/Pre-Bid Date and Time	प्री-बिड स्थान/Pre-Bid Venue
13-10-2025 12:00:00	Please refer to the TIFR Hyderabad Tender page for the Zoom link. TIFR Hyderabad premises. Please refer tender details

Online Ups Modular Type (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

[* जेम कैटेगरी विशिष्टि के अनुसार / As per GeM Category Specification](#)

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Output power capacity including redundancy/Expandable (Rack facility) upto/Minimum backuptime (including redundancy) /Minimum VAH (VAH shall be calculated Battery voltage x Battery Ah x No. of batteries = Total VAH)	120 KVA / 125 KVA / 30 Minutes / 76800 VAH
	Noise level	</= 65 dB
INPUT	In put Voltage Range	340 V to AC to 470 V AC 3 Phase
	Input frequency range	50 +/-10% Hz
	Distortion (current)	< / = 3%
OUTPUT	Output powr factor	>/=0.99

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
CONSTRUCTION	Minimum thickness (in mm) of Rack Enclosure for Modular UPS duly powder coated	1.2
	UPS enclosure's degree of protection as per IS:13947 (Part 1)/1993 latest	IP20
	Total Harmonic Distortion (THD) for 100% linear load	< 2%
	Total Harmonic Distortion (THD) for 100% non-linear load	< 5%
	Over all efficiency on rated full load of 0.8 PF (min.) AC output	>=96%
	Inverter efficiency on rated full load of 0.8 PF (min.) AC output	>=96%
	UPS shall withstand Over load capacity - 125% (Output with mains AC-AC)	for 5 Minutes (Minimum)
	UPS shall withstand Over load capacity - 125% (Output in battery run DC-AC)	for 2 Minutes (Minimum)
BATTERY	Battery type	SMF VRLA
	Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD	8 to 10 hours
	Batteries shall supply with	With metal rack
WARRANTY AND SERVICES	Warranty for Modular UPS (on site comprehensive warranty) (in years)	others
	Warranty for battery (replacement warranty) (in years)	2
	After sales and complaint service	within 24 hours
	PAN India service support on 24 x 7 basis	Yes
	AMC support available after 3 year warranty	Yes
	Quarterly preventive maintenance	Yes

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Manufacturer shall provide and support for installation, commissioning, spares, technical support all over India	Yes
	Availability of spares in close proximity (Spares should be easily available close to the site)	Yes
CERTIFICATIONS	ISO: 9001 Certification	Yes
	CE Certification and marking	Yes
	Damp Heat Test : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007)	Yes
	Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs	Yes
	Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajasekhar Rajapurmath	500019,Sy No 36/P Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, 500046	1	90

Online Ups Modular Type (1 pieces)

(क्रमशः श्रेणी 1 और श्रेणी 2 के स्थानीय आपूर्तिकर्ता के रूप में अर्हता प्राप्त करने के लिए आवश्यक/Minimum 50% and 20% Local Content required for qualifying as Class 1 and Class 2 Local Supplier respectively)

तकनीकी विशिष्टियाँ /Technical Specifications

* जेम केटेगरी विशिष्टि के अनुसार / As per GeM Category Specification

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
GENERIC	Output power capacity including redundancy/Expandable (Rack facility) upto/Minimum backuptime (including redundancy) /Minimum VAH (VAH shall be calculated Battery voltage x Battery Ah x No. of batteries = Total VAH)	60 KVA/120KVA/30 Minutes/49200 VAH
	Noise level	</= 65 dB
INPUT	In put Voltage Range	340 V to AC to 470 V AC 3 Phase
	Input frequency range	50 +/-10% Hz
	Distortion (current)	< / = 3%
OUTPUT	Output powr factor	>/=0.99
CONSTRUCTION	Minimum thickness (in mm) of Rack Enclosure for Modular UPS duly powder coated	1.2
	UPS enclosure's degree of protection as per IS:13947 (Part 1)/1993 latest	IP21
	Total Harmonic Distrotion (THD) for 100% linear load	< 3%
	Total Harmonic Distrotion (THD) for 100% non-linear load	< 5%
	Over all efficiency on rated full load of 0.8 PF (min.) AC output	>/=96%
	Inverter efficiency on rated full load of 0.8 PF (min.) AC output	>/=96%
	UPS shall withstand Over load capacity - 125% (Output with mains AC-AC)	for 10 Minutes (Minimum)
	UPS shall withstand Over load capacity - 125% (Output in battery run DC-AC)	for 30 Seconds (Minimum)
BATTERY	Battery type	SMF VRLA

विवरण/Specification	विशिष्टि का नाम /Specification Name	बिड के लिए आवश्यक अनुमत मूल्य /Bid Requirement (Allowed Values)
	Battery recharge time (after complete discharge to 90% charge) and charge rating: Battery recharge time to 90% charge after 100% DoD	8 to 10 hours
	Batteries shall supply with	With metal rack
WARRANTY AND SERVICES	Warranty for Modular UPS (on site comprehensive warranty) (in years)	3
	Warranty for battery (replacement warranty) (in years)	2
	After sales and complaint service	within 24 hours
	PAN India service support on 24 x 7 basis	Yes
	AMC support available after 3 year warranty	Yes
	Quarterly preventive maintenance	Yes
	Manufacturer shall provide and support for installation, commissioning, spares, technical support all over India	Yes
	Availability of spares in close proximity (Spares should be easily available close to the site)	Yes
CERTIFICATIONS	ISO: 9001 Certification	Yes
	CE Certification and marking	Yes
	Damp Heat Test : in accordance with IS:9000(part 5/sec.2)1981 at Temperature of 40 degree C,two cycles of (12+12) hours each 2007)	Yes
	Dry Heat Test : in accordance with IS:9000 (part 3/sec.5)1977 (reaffirmed 2007) at 55 degree C for 16 hrs	Yes
	Cold Test : in accordance with IS:9000 (Part 2/Sec.4)1977 (Reaffirmed 2007) at -10 degree C for 4 hrs.	Yes

परेषिती/रिपोर्टिंग अधिकारी तथा मात्रा/Consignees/Reporting Officer and Quantity

क्र.सं./S.No.	परेषिती/रिपोर्टिंग अधिकारी /Consignee Reporting/Officer	पता/Address	मात्रा /Quantity	डिलीवरी के दिन/Delivery Days
1	Rajasekhar Rajapurmath	500019,Sy No 36/P Gopanpally Village, Serilingampally Mandal, Ranga Reddy District, 500046	1	90

Buyer added Bid Specific Additional Scope of Work

क्र.सं./S.No.	Document Title	Description	रिवर्स प्रभार के अनुसार जीएसटी/Applicable i.r.o. Items
1	Supply, Installation, Testing and Commissioning of 120 KVA and 60 KVA UPS View	Supply, Installation, Testing, and Commissioning of 120 KVA Modular -N plus 1 Modules UPS-1 No and 60 KVA Modular- N plus 1 Modules UPS-1 No with 30 minutes battery backup and all related Works for Labs at TIFR, Hyderabad as per the Scope of Work Document	Online Ups Modular Type(1),Online Ups Modular Type(1)

The uploaded document only contains Buyer specific Additional Scope of Work and / or Drawings for the bid items added with due approval of Buyer's competent authority. Buyer has certified that these additional scope and drawings are generalized and would not lead to any restrictive bidding.

क्रेता द्वारा जोड़ी गई बिड की विशेष शर्तें/Buyer Added Bid Specific Terms and Conditions**1. Generic**

OPTION CLAUSE: The Purchaser reserves the right to increase or decrease the quantity to be ordered up to 25 percent of bid quantity at the time of placement of contract. The purchaser also reserves the right to increase the ordered quantity up to 25% of the contracted quantity during the currency of the contract at the contracted rates. The delivery period of quantity shall commence from the last date of original delivery order and in cases where option clause is exercised during the extended delivery period the additional time shall commence from the last date of extended delivery period. The additional delivery time shall be $(\text{Increased quantity} \div \text{Original quantity}) \times \text{Original delivery period (in days)}$, subject to minimum of 30 days. If the original delivery period is less than 30 days, the additional time equals the original delivery period. The Purchaser may extend this calculated delivery duration up to the original delivery period while exercising the option clause. Bidders must comply with these terms.

2. Scope of Supply

Scope of supply (Bid price to include all cost components) : Supply Installation Testing Commissioning of Goods and Training of operators and providing Statutory Clearances required (if any)

3. Buyer Added Bid Specific ATC

CUSTOM BID

BID DESCRIPTION: Supply, Installation, Testing and Commissioning of 120 KVA Modular (N+1 Modules) UPS-1 No and 60 KVA Modular (N+1 Modules) UPS-1 No with 30 minutes battery backup and all related Works for Labs at TIFR, Hyderabad as per the Scope of Work Document.

● **Eligibility criteria:**

1. UPS OEMs or authorized channel partners only are eligible to submit the offer. Copy of authorization to be enclosed.
2. The Agencies/Contractors shall require to submit IT Returns for the last three consecutive financial years ended on March 31, 2024 audited by Chartered Accountant.
3. The Agencies/Contractors should have an average annual turnover of Rs.11.89 lakhs during three previous financial years ending March 31, 2024 duly certified by Chartered Accountant.
4. The Agencies/Contractors should have valid PAN from Income Tax Authority, GST registration No. etc., and any other registration applicable/mandatory for the contract.
5. Quoted UPS model shall meet all the technical specifications and compliance with the technical data sheet (Catalogue of the quoted UPS model must be attached)
6. The Agencies/Contractors should have executed similar UPS installations for data centres or IT works or other facilities successfully at least
 1. One similar work costing Rs.19.02 Lakhs or
 2. Two similar works costing Rs. 11.89 Lakhs or
 3. Three similar works costing Rs. 9.51 Lakhs during the last 7 financial years ended on the end date of receiving tender for Research Institutes, Universities, Private Laboratories, R&D institutes, etc. in any Government /PSU/Private organizations of repute.

The Agencies/Contractors should furnish copies of work orders and completion certificates/CRAC document from the clients in support of the above.

7. The Agencies/Contractors shall require to submit Certificate of Local Content
8. The Agencies/Contractors shall be required to provide the acceptance of bid terms & conditions/scope of work.

-

Information and Instructions to Bidder

1) **Payment:** One Running Bill is allowed with 35% of the contract order value against the material supply and acceptance with duly certify by the TIFR Hyderabad Officials. The final bill will be after successful commissioning of equipment along with all relevant documents including original manufacturer's warranty duly certify by the TIFR Hyderabad Officials. All bills will be due within 30 days upon receipt of original invoice along with all relevant documents.

2) The Contractor should adhere to the building bye-laws applicable for the area.

3) The submission of the bid by the bidder would imply that they have carefully read and agree to the terms and conditions contained in this bid document.

4) Canvassing, either directly or indirectly, in connection with the tenders is strictly prohibited and the bids submitted by the bidders who resort to canvassing will be liable to rejection.

5) Liquidated Damages: For all delays, which do not merit any extension of time, the

Bidder/ Supplier shall pay penalty or Liquidated Damages (LD) to the TIFR, Hyderabad at the rate of 0.5% of the contract value per week for delay in completion of work subject to the maximum 10 per cent of the contract value.

The amount of Liquidated Damages shall be recoverable from the payment due to the Bidder/Supplier up to maximum of 10% of value of contract. The deduction of Liquidated Damages shall not, however, absolve the Bidder/Supplier of his responsibility and obligations under the contract to complete the work in its entirety and shall also be without prejudice to action by the TIFR, Hyderabad under clause: 'Termination of contract by the TIFR, Hyderabad'. After that the same shall be completed by the TIFR, Hyderabad at the Bidder's/Supplier's risk and cost.

4. Certificates

Bidder's offer is liable to be rejected if they don't upload any of the certificates / documents sought in the Bid document, ATC and Corrigendum if any.

5. Certificates

The bidder is required to upload, along with the bid, all relevant certificates such as BIS licence, type test certificate, approval certificates and other certificates as prescribed in the Product Specification given in the bid document.

6. Service & Support

Availability of Service Centres: Bidder/OEM must have a Functional Service Centre in the State of each Consignee's Location in case of carry-in warranty. (Not applicable in case of goods having on-site warranty). If service center is not already there at the time of bidding, successful bidder / OEM shall have to establish one within 30 days of award of contract. Payment shall be released only after submission of documentary evidence of having Functional Service Centre.

7. Service & Support

Escalation Matrix For Service Support : Bidder/OEM must provide Escalation Matrix of Telephone Numbers for Service Support.

8. Forms of EMD and PBG

Bidders can also submit the EMD with Account Payee Demand Draft in favour of

Tata Institute of Fundamental Research, Hyderabad
payable at
Hyderabad

Bidder has to upload scanned copy / proof of the DD along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

9. Forms of EMD and PBG

Bidders can also submit the EMD with Fixed Deposit Receipt made out or pledged in the name of A/C

Tata Institute of Fundamental Research, Hyderabad
. The bank should certify on it that the deposit can be withdrawn only on the demand or with the sanction of the pledger. For release of EMD, the FDR will be released in the favour of the bidder by the Buyer after making endorsement on the back of the FDR duly signed and stamped along with covering letter. Bidder has to upload scanned copy/ proof of the FDR along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date/ Bid Opening date

10. Forms of EMD and PBG

Successful Bidder can submit the Performance Security in the form of Account Payee Demand Draft also (besides PBG which is allowed as per GeM GTC). DD should be made in favour of

Tata Institute of Fundamental Research, Hyderabad
payable at
Hyderabad

. After award of contract, Successful Bidder can upload scanned copy of the DD in place of PBG and has to ensure delivery of hard copy to the original DD to the Buyer within 15 days of award of contract.

11. **Forms of EMD and PBG**

Bidders can also submit the EMD with Banker's Cheque in favour of

Tata Institute of Fundamental Research, Hyderabad
payable at
Hyderabad

. Bidder has to upload scanned copy / proof of the BC along with bid and has to ensure delivery of hardcopy to the Buyer within 5 days of Bid End date / Bid Opening date.

12. **Buyer Added Bid Specific ATC**

Buyer uploaded ATC document [Click here to view the file.](#)

अस्वीकरण/Disclaimer

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization, whereby Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome, and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specifications and / or terms and conditions governing the bid. If any clause(s) is / are incorporated by the Buyer regarding following, the bid and resultant contracts shall be treated as null and void and such bids may be cancelled by GeM at any stage of bidding process without any notice:-

1. Definition of Class I and Class II suppliers in the bid not in line with the extant Order / Office Memorandum issued by DPIIT in this regard.
2. Seeking EMD submission from bidder(s), including via Additional Terms & Conditions, in contravention to exemption provided to such sellers under GeM GTC.
3. Publishing Custom / BOQ bids for items for which regular GeM categories are available without any Category item bunched with it.
4. Creating BoQ bid for single item.
5. Mentioning specific Brand or Make or Model or Manufacturer or Dealer name.
6. Mandating submission of documents in physical form as a pre-requisite to qualify bidders.
7. Floating / creation of work contracts as Custom Bids in Services.
8. Seeking sample with bid or approval of samples during bid evaluation process. (However, in bids for [attached categories](#), trials are allowed as per approved procurement policy of the buyer nodal Ministries)
9. Mandating foreign / international certifications even in case of existence of Indian Standards without specifying equivalent Indian Certification / standards.
10. Seeking experience from specific organization / department / institute only or from foreign / export experience.
11. Creating bid for items from irrelevant categories.
12. Incorporating any clause against the MSME policy and Preference to Make in India Policy.
13. Reference of conditions published on any external site or reference to external documents/clauses.
14. Asking for any Tender fee / Bid Participation fee / Auction fee in case of Bids / Forward Auction, as the case may be.
15. Buyer added ATC Clauses which are in contravention of clauses defined by buyer in system generated bid template as indicated above in the Bid Details section, EMD Detail, ePBG Detail and MII and MSE Purchase Preference sections of the bid, unless otherwise allowed by GeM GTC.

16. In a category based bid, adding additional items, through buyer added additional scope of work/ additional terms and conditions/or any other document. If buyer needs more items along with the main item, the same must be added through bunching category based items or by bunching custom catalogs or bunching a BoQ with the main category based item, the same must not be done through ATC or Scope of Work.

Further, if any seller has any objection/grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

All GeM Sellers / Service Providers are mandated to ensure compliance with all the applicable laws / acts / rules including but not limited to all Labour Laws such as The Minimum Wages Act, 1948, The Payment of Wages Act, 1936, The Payment of Bonus Act, 1965, The Equal Remuneration Act, 1976, The Payment of Gratuity Act, 1972 etc. Any non-compliance will be treated as breach of contract and Buyer may take suitable actions as per GeM Contract.

[यह बिड सामान्य शर्तों के अंतर्गत भी शासित है /This Bid is also governed by the General Terms and Conditions](#)

जेम की सामान्य शर्तों के खंड 26 के संदर्भ में भारत के साथ भूमि सीमा साझा करने वाले देश के बिडर से खरीद पर प्रतिबंध के संबंध में भारत के साथ भूमि सीमा साझा करने वाले देश का कोई भी बिडर इस निविदा में बिड देने के लिए तभी पात्र होगा जब वह बिड देने वाला सक्षम प्राधिकारी के पास पंजीकृत हो। बिड में भाग लेते समय बिडर को इसका अनुपालन करना होगा और कोई भी गलत घोषणा किए जाने व इसका अनुपालन न करने पर अनुबंध को तत्काल समाप्त करने और कानून के अनुसार आगे की कानूनी कार्रवाई का आधार होगा।/In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

---धन्यवाद/Thank You---